TRENT RIVER AUTHORITY

WATER RESOURCES ACT, 1963

RIVERS (PREVENTION OF POLLUTION) ACTS, 1951—61

File Reference B.5011

T/69/03170/5

Consent No. 2170

TO:

R. Nokes, Esq.,
Scarthingmoor Farm,
Weston,
Near Newark,
Nottinghamshire.

THE TRENT RIVER AUTHORITY in pursuance of the powers conferred on them by the above-mentioned Acts HEREBY CONSENT to your
bringing into use a new outlet for the discharge of effluent to a stream
beginning to make a new discharge of effluent to a stream
continuing to make a discharge of effluent to a stream

as described below, the subject of your application dated 20th March 1963

SUBJECT to the conditions set out herein.

Description of outlet

Existing outlet to a tributary of the River Trent as shown marked "Outfall" on Drawing No. T.R.A. 3176/1 and located within O.S. National Grid Square SK 752 68).

Description of effluent

Discharge of sewage effluent from the sewage treatment plant serving Gypsy Lodge Farm, Egmanton, Near Newark, Nottinghamshire.

Dated this Eleventh day of April 1972

206, Derby Road,
Nottingham.
NG7 1NT

Clerk of the Authority.

CONDITIONS ATTACHED TO CONSENT

1. The effluent discharged to the stream shall not:-

   (a) have a Biochemical Oxygen Demand (5 days) in excess of 40 milligrams per litre;

   (b) contain suspended solids in excess of 60 milligrams per litre.

2. The volume of effluent discharged to the stream shall not exceed 700 litres per day.

The terms of this Consent will not, without the consent in writing of the person to whom this Consent is given (or his successor), be altered before the expiration of the period ending with the eleventh day of April 1976