



OUTGOING

CONTROL OF POLLUTION ACT 1974

WASTE DISPOSAL LICENCE

1. The Waste Regulation Authority hereby grant a Waste Disposal Licence to
Wessex Water Services Limited of Passage Street, Bristol, Avon

for land occupied at Trowbridge Sewage Treatment Works, Bradford Road, Trowbridge

subject to the conditions listed overleaf.

2. This licence is issued in accordance with Part 1 of the Control of Pollution Act 1974. The licence holder must ensure that all other relevant legislation is complied with. Attention is particularly draw to the Health and Safety at Work etc. Act 1974, the Radioactive Substances Act 1960 and planning, water protection and environmental health legislation.

NOTES

Rights of Appeal

If a licence holder is aggrieved by the decision of the Waste Regulation Authority in granting a licence subject to conditions he may appeal to the Secretary of State in accordance with Section 10 of the Control of Pollution Act 1974. Appeals must be notified within 6 months of the date of this licence to The Secretary of State, Department of the Environment, Waste Disposal Division, Queen Anne's Chambers, 28 Broadway, London SW1R 9JU. The Secretary of State has power to allow a longer period for the giving of notice of an appeal, but he will not normally be prepared to exercise this power unless there are special circumstances which excuse the delay in giving notice of an appeal.

Dated this 5th day of August 1993

Signed

R. V. Brown

Authorised Officer

Operational Conditions

3. Handling of waste within the works shall only be during normal working hours.
4. The quantity of waste deposited for direct discharge into the facility shall be carefully controlled to ensure that the operation of the sewage treatment process is not prejudiced.
5. Precautions shall be taken while waste is being discharged from tankers to prevent any spillage.
6. A record shall be kept of all the waste delivered to the facility. This record shall include as a minimum requirement details of the following:
 - Origin of Waste
 - Type of Waste
 - Quality of Waste
 - Waste Carrier and Vehicle Registration Number
 - Method of dealing with waste
 - Sampling and testing undertaken upon delivery
 - Any load rejected or held pending further investigations (including reasons for rejection and/or further actions taken)
7. A record shall be kept of spillages or other accidents at the facility.
8. A record shall be kept of all analytical data relating to the acceptability checks.
9. No waste shall be deposited for direct discharge at the facility unless a representative sample of the Waste Stream has been previously tested in accordance with the Operating Plan to ensure that the waste is wholly compatible with the sewage treatment process, and will not give rise to any adverse reactions when intermixed with other approved wastes. This testing shall be repeated at regular intervals to ensure consistency of the Waste Streams.
10. Each individual load of previously approved waste delivered to the facility shall be sampled and tested in accordance with the Operating Plan.

This testing shall be sufficient to identify any deviations from the approved specification for that waste stream.

Any individual load which is significantly outside the approved specification for that waste stream shall not be accepted and the Waste Disposal Authority shall be notified forthwith.
11. No waste shall be deposited at the facility without the prior consent of the Operational Manager.

12. No waste shall be deposited at the facility unless operational areas are surfaced with a hard, durable, impermeable material capable of taking loaded vehicles without deformation.
13. Such action as may be reasonably be necessary shall be taken to prevent the deposit of waste or mud on public highways by vehicles using the site.
14. The terms of the licence shall be made known to any persons who is given responsibility for the management of or control of the site and a copy of this shall be displayed at the site control office.
15. In the event that liquid waste should be spilt from a consignment of waste being brought in, the licence holder shall provide on site and adjacent to the facility a supply of suitable absorbent material.

All works undertaken to comply with Condition 15 shall be completed to the satisfaction of the Waste Regulation Authority following its consultation with the National Rivers Authority (Wessex Region).

