

W00314 22Feb78 Reg Card

CR 1310C
PP(A)38/L8/HL2

REGISTER OF CONDITIONS

AND OTHER TERMS
IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

CH. NO. B.112 SHAW & SHAW LTD., FETTER LANE, E.C.4

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
22nd February, 1978 to 22nd February, 1980	Southern Water Authority, Hampshire River and Water Division Hampshire Drainage Division Eastleigh House, 2, Market Street, Eastleigh, Hants.
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
CONDITIONS IMPOSED WITH RESPECT TO:-	CONDITIONS IMPOSED WITH RESPECT TO:-
(i) PRECISE LOCATION OF OUTLET Grid Reference SU 4362 1484	(i) NATURE AND COMPOSITION OF DISCHARGE The effluent discharged into the relevant waters shall comply with the following standard:- (a) Biochemical Oxygen Demand in 5 days at 20°C not to exceed 20 mg/l (b) Suspended Solids dried at 105°C not to exceed 30 mg/l
(ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) The outlet shall be constructed and maintained in accordance with the drawings submitted with the Application.	(ii) TEMPERATURE OF DISCHARGE
(iii) USE OF OUTLET The outlet at Grid Reference SU 4362 1484 shall be used only for the discharge of treated sewage effluent.	(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES The volume of the effluent discharged under dry weather conditions shall not exceed 27,700 m ³ in any period of 24 hours. * (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's Officers shall be provided and maintained at the cascade chamber as indicated on the drawing numbered 409/102 submitted by the Applicant.
(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	(iv) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S.5(2) OF 1961 ACT
REMARKS-	REMARKS-

W000314 22 Feb 78 EMC Reg Card A

REGISTER OF CONDITIONS

(R1303

AND OTHER LAWS
IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

Application No. PP(A)38/48/71;
Ct. No. R.12 5000 3 5000 100 - 10000 1000 1000 1000

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
22nd February, 1978 to 22nd February, 1980	Southern Water Authority, Hampshire River and Water Division, Hampshire Drainage Division, Eastleigh House, 2, Market Street, EASTLEIGH.
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
CONDITIONS IMPOSED WITH RESPECT TO:- (i) PRECISE LOCATION OF OUTLET Grid Reference SU 4358 1493	CONDITIONS IMPOSED WITH RESPECT TO:- (i) NATURE AND COMPOSITION OF DISCHARGE
(ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) The outlet shall be constructed and maintained in accordance with the drawings submitted by the Applicant.	(ii) TEMPERATURE OF DISCHARGE
(iii) USE OF OUTLET The outlet C at Grid Reference SU 4358 1493 shall be used only for the discharge of crude sewage in an emergency. The discharge shall not occur except in an emergency caused by failure of the public electricity supply and coincident failure of the standby generating plant.	(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES The volume of effluent discharged under dry weather conditions shall not exceed 27,700 m ³ in any period of 24 hours. (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's Officers shall be provided and maintained at outlet C indicated on plan numbered W409/53 submitted by the applicant.
(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	(v) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT
REMARKS-	REMARKS-

100314 22 Feb 78 Storm Reg Contd A

REGISTER OF CONDITIONS

CR 1310 A

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951 AND OTHER TERMS
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

Application No. FP(A)38/ML2

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
22nd February, 1978 to 22nd February, 1980	Southern Water Authority, Hampshire River and Water Division, Hampshire Drainage Division, Pastleigh House, 2, Market Street, Eastleigh, Hants. Portsmouth Sewage Works, Portsmouth, Hants.
USE OF NEW OR ALTERED OUTLET	
CONDITIONS IMPOSED WITH RESPECT TO:-	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
(i) PRECISE LOCATION OF OUTLET Grid Reference SU 4358 1459	(ii) NATURE AND COMPOSITION OF DISCHARGE
(iii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) The outlet shall be constructed and maintained in accordance with the drawings submitted by the Applicant.	(iii) TEMPERATURE OF DISCHARGE
(iii) USE OF OUTLET The outlet at Grid Reference SU 4358 1459 shall be used only for the discharge of settled storm sewage and in an emergency crude sewage at Outlet B. The discharge of crude sewage shall not occur except in an emergency caused by failure of the public electricity supply and coincident failure of standby generators.	(iii) VOLUME OR RATE OF DISCHARGE OF The volume of storm sewage discharges to the effluent from land or premises to the relevant waters at outlet B shall be limited to that resulting from the overflow of sewage at the storm sewage separating weir of flows in excess of 1000 litres per second and the discharge shall take place for so long as an overflow is occurring from the storm tanks.
(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	*(iv) PROVISION OF FACILITIES FOR TAKING SAMPLES. Facilities for the taking of samples by the Authority's Officers shall be provided and maintained at points B, B1 and B2 indicated on the plan numbered V409/53 submitted by the Applicant.
(iv) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S.5(2) OF 1951 ACT	
REMARKS-	REMARKS-
	Consent given JS 100314 22 Feb 78 Storm Reg Contd A

W00314 22 Feb 78 Enq Reg Card

REGISTER OF CONDITIONS

No. P(A) 38/15/112/76

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

CRT. No. 12 5000 8 5000 LTH. LITTON LANE, E.C.4.

W00314

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
22nd February 1978	Southern Water Authority Hampshire River and Water Division, Hampshire Drainage Division, Eastleigh House, 2 Market Street, Eastleigh, Hants.
USE OF NEW OR ALTERED OUTLET	
CONDITIONS IMPOSED WITH RESPECT TO:-	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
(i) PRECISE LOCATION OF OUTLET Portsmouth Sewage Works, Portsmouth, Hampshire.	(i) NATURE AND COMPOSITION OF DISCHARGE
(ii) CONSTRUCTION OF OUTLET OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE: The outlet shall be constructed and maintained in accordance with the drawings submitted by the Applicant.	(ii) TEMPERATURE OF DISCHARGE
(iii) USE OF OUTLET The outlet at C at Grid Reference SU 4358 1493 shall be used only for the discharge of crude sewage in an emergency. The discharge shall not occur except in an emergency caused by failure of the public electricity supply and coincident failure of the standby generating plant.	(iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES The volume of the effluent discharged under dry weather conditions shall not exceed 27,700 m ³ in any period of 24 hours. * (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's Officers shall be provided and maintained at outlet C indicated on the plan numbered V409/53 submitted by the applicant.
(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	(v) DATE OF EXPIRATION OF PERIOD SPECIFIED The terms of this consent shall not under s.3(2) of 1961 Act without the consent in writing of the person to whom this consent is given (or his successor) be altered before the expiration of the period ending with the 22nd day of February 1980
REMARKS-	REMARKS-

W00314 22 Feb 78 Sharn
Reg Cond 6

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951

(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)

AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. PP(A) 28/43/H/2/76

Cat. No. R.B.12 Size 8 5000 Lm. (Fitted Lamin. P.C.A.)

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
22nd February 1978	Southern Water Authority Hampshire River and Water Division Hampshire Drainage Division Bastleigh House, 2 Market Street, Bastleigh, Hants
USE OF NEW OR ALTERED OUTLET	
CONDITIONS IMPOSED WITH RESPECT TO:-	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
(ii) PRECISE LOCATION OF OUTLET Portsmouth Sewage Works, Portsmouth, Hampshire	(iii) CONDITIONS IMPOSED WITH RESPECT TO:- (iv) NATURE AND COMPOSITION OF DISCHARGE
(iii) CONSTRUCTION OF OUTLET OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE The outlet shall be constructed and maintained in accordance with the drawings submitted by the Applicant.	(iii) TEMPERATURE OF DISCHARGE
(iii) USE OF OUTLET The outlet at Grid Reference SU 4358 1459 shall be used only for the discharge of settled storm sewage and in an emergency crude sewage at outlet B. The discharge of crude sewage shall not occur except in an emergency caused by failure of the public electricity supply and coincident failure of standby generators.	(iii) VOLUME OR RATE OF DISCHARGE OF The volume of storm sewage discharged to EFFLUENT FROM LAND OR PREMISES the relevant waters at outlet B shall be limited to that resulting from the overflow of sewage at the storm sewage separating weir of flows in excess of 1000 litres per second and the sewage shall take place for so long as an overflow is occurring from the (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's Officers shall be provided and maintained at points B, H1 and B2 indicated on the plan numbered V409/53 submitted by the Applicant.
(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	(iv) DATE OF EXPIRATION OF PERIOD SPECIFIED The terms of this consent shall not UNDER S.5(2) OF 1961 ACT without the consent in writing of the person to whom this consent is given (or his successor) be altered before the expiration of the period ending with the 22nd day of February 1980
REMARKS-	REMARKS-