

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: **NORTH WEST WATER LTD
DAWSON HOUSE
LIVERPOOL RD, GREAT SANKEY
WARRINGTON
CHESHIRE
WA5 3LW**

Contact Name (if applicable): **ANGELA WELLS**
Registered as Joint Consent Holder: **No**

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent **0169982852** from 1 December 1996

Consent Alias (if applicable): **SAL0188**
Sample Point Grid Reference: **SD78450355**

Nature of Discharge(s): **TREATED SEWAGE**
at **WYNNE AVENUE PUMPING STATION PENDLEBURY LANCs**

PLEASE NOTE: For Consents with Multiple Discharges, see the attached Schedule.

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To: **Environment Agency P.O. Box 12 Richard Fairclough House Knutsford Road Warrington WA4 1HG**
Tel: 01925 653999 Fax: 01925 242209

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: **0169982852** Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):
Address:

Post Code:

Date of Transfer to new Holder(s);

Signed: Dated:

Name (block capitals): Position:

JWE/5/96

(to be completed when signing
on behalf of corporate bodies)



Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

**To: NORTH WEST WATER LTD
DAWSON HOUSE
LIVERPOOL RD, GREAT SANKEY
WARRINGTON
CHESHIRE
WA5 3LW**

Contact Name (if applicable): **ANGELA WELLS**
Registered as Joint Consent Holder: **No**

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent **SAL0188** from 1 October 1996.

Consent Alias (if applicable): **016992852**
Sample Point Grid Reference: **SD 7845 0355**

Nature of Discharge(s): **EMERGENCY/CRUDE SEWAGE**
at **WYNNE AVENUE PUMPING STATION PENDLEBURY LANCASHIRE**

PLEASE NOTE: For Consents with Multiple Discharges, see the attached Schedule.

NOTE: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

**To: Environment Agency P.O. Box 12 Richard Fairclough House Knutsford Road Warrington WA4 1HG
Tel: 01925 653999 Fax: 01925 242209**

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: SAL0188

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s);

Signed:.....

Dated:.....

Name (block capitals):

Position:

JWB/S/96

(to be completed when signing on behalf of corporate bodies)



NATIONAL RIVERS AUTHORITY - NORTH WEST REGION 22/96

NWW No. SAL 0188

CONSENT NO.016982852

WATER RESOURCES ACT 1991
CONSENT TO DISCHARGE

Consent of the National Rivers Authority (hereinafter called "the Authority") is hereby granted to

**North West Water Ltd
Dawson House
Liverpool Road
Great Sankey
Warrington
WA5 3LW**

to discharge sewage from the emergency overflow at Wynne Avenue Pumping Station, Pendlebury, Lancashire to "controlled waters" within the area of the Authority, namely the River Irwell subject to the following conditions:-

1. Nature

The discharge shall consist solely of sewage discharged in an emergency, when the sewage pumping station is inoperative as a result of one or more of the following:

- (i) electrical power failure not due to the act or default of the discharger, it's agents, representatives, officers, employees or servants;
- (ii) mechanical breakdown of duty and standby pumps;
- (iii) rising main failure;
- (iv) blockage of the downstream sewer not due to the act or default of the discharger, it's agents, representatives, officers, employees or servants;

and it is not reasonably practicable to dispose of the sewage otherwise. There shall be no undue delay on the part of the discharger in remedying any such failure or breakdown.

2. Telemetry

A 24 hour response telemetry alarm system shall be provided and maintained to provide a notification of failure or breakdown of the pumping station. The system shall be tested on a regular basis, as agreed in writing with the Authority, to ensure that it is functioning satisfactorily. The discharger shall keep a record of the test results available for inspection by the Authority.

3. Response Time

Following installation of the pumping station failure or breakdown telemetry system, the discharger shall take all reasonable remedial measures, as soon as is reasonably practicable after receipt of warning of failure or breakdown of the pumping station, to return the pumping station to normal operation.

4. Power

Facilities shall be provided so that a mobile stand-by generator may readily be installed at the pumping station in the event of electrical failure.

5. Pumps

The duty pump(s) shall be maintained in good working order, and at least one stand-by pump shall be provided and maintained at all times.

Stand-by pump(s) shall activate automatically should the duty pump(s) become inoperative for reasons other than power failure. The pumping station shall be maintained so that the pump(s) shall reactivate immediately after the power is restored following interruption to the supply.

An external pumping equipment facility shall be provided and maintained for use in the event of the installed pumps being inoperative.

6. Storage

Storage capacity of at least 74 cubic metres shall be provided in the pumping station wet well and/or the upstream sewerage system above the wet well top float level.

7. Records

- (a) The discharger shall establish and operate a documented maintenance programme and record all non-routine actions undertaken. Copies of the programme shall be made available for inspection by the Authority's officers at all reasonable times.
- b) The discharger shall supply the Authority with an annual written report on the operation of the maintenance programme and all non-routine actions. The contents and format of the report to be agreed in writing with the Authority.

8. Clean-Up

Where the discharge results in unsatisfactory solid matter being visible in the receiving watercourse or on the banks of the receiving watercourse, in the vicinity of the outfall, the discharger shall take all reasonable steps to collect and remove such matter as soon as reasonably practicable after the discharge has been reported.

General Conditions

9 Discharge Point Location

The discharge shall be made from an outlet at National Grid Reference SJ 7845 0355 into the River Irwell.

10. Sampling Points


A sampling point at National Grid Reference SD 7845 0355 shall be constructed and maintained so that a representative sample of the storm sewage discharged may be obtained. The discharger shall ensure that all constituents of the discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the storm sewage taken at the said sampling point is a sample of what is discharging into controlled waters.

Subject to the provisions of Paragraphs 6 and 7 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Authority, altering this consent without the agreement in writing of the discharger, during a period of 2 years from the date this Consent takes effect.

This Consent supersedes the Consent numbered 016992852 issued on the 17th November, 1994.

Dated this 23rd day of January 1996

Signed



Dr Susan Walker
Area Manager