

Notice of variation with introductory note

The Environmental Permitting (England & Wales) Regulations 2010

The National Trust

Sewage treatment plant and infiltration system serving
Kingston Lacy House
Wimborne
Dorset
BH21 4DS

Variation application number

050995/V002

Permit number

050995

Sewage treatment plant and infiltration system serving Kingston Lacy House

Permit number 050995

Introductory note

This introductory note does not form a part of the notice

The following notice gives notice of the variation of an environmental permit.

This variation is undertaken at the request of the operator to increase the maximum daily discharge volume from 15 cubic metres per day to 45 cubic metres per day to reflect increasing visitor numbers at the site. The site will be served by a package treatment plant & infiltration system treating to 5 milligrams per litre of ammoniacal nitrogen.

The schedules specify the changes made to the original permit.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit		
Description	Date	Comments
Original permit issued 050995	20/05/83	Permit issued to The National Trust.
Regulator initiated variation determined 050995/V001	17/12/12	EPR and GWDD update
Application 050995/V002 (variation)	Duly made 27/07/16	Application to vary the permit.
Additional information received	17/10/16	Revised risk assessment.
Variation determined 050995/V002	08/11/2016	Varied permit issued.

End of introductory note

Notice of variation

Environmental Permitting (England and Wales) Regulations 2010

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 varies

Permit number

050995

Issued to

The National Trust ("the operator")

whose principal office is

Heelis

Kemble Drive

Swindon

Wiltshire

SN2 2NA

to operate a groundwater activity at

Kingston Lacy House

Wimborne

Dorset

BH21 4DS

to the extent set out in the schedules.

The notice shall take effect from 08/11/2016

Name	Date
Joseph Tidbury	08/11/2016

Authorised on behalf of the Environment Agency

Schedule 1 – conditions to be deleted

None

Schedule 2 – conditions to be amended

The following conditions are amended as a result of the application made by the operator

Effluent(s) and discharge point(s)	Parameter	Limit (including unit)	Reference Period	Limit of effective range	Monitoring frequency	Compliance Statistic
Secondary treated sewage effluent via Outlet 1	Maximum daily discharge volume	45 m ³ /day	Total daily volume	N/A	N/A	Maximum
	BOD : 5 Day ATU	20 mg/l	Instantaneous (spot sample)	N/A	N/A	Maximum
	Solids, Suspended at 105 C	30 mg/l	Instantaneous (spot sample)	N/A	N/A	Maximum
	Ammoniacal nitrogen (expressed as N)	5 mg/l	Instantaneous (spot sample)	N/A	N/A	Maximum
	Visible oil or grease	No significant trace present so far as is reasonably practicable	Instantaneous (visual examination)	N/A	N/A	No significant trace

Schedule 3 – conditions to be added

None

Schedule 4 – amended plan

Amended plan attached

