

Rivers (Prevention of Pollution) Acts 1951 - 1961The Water Authorities (Control of Outlets and Discharges) Regulations 1975

To : The Southern Water Authority
Hampshire Drainage Division

TAKE NOTICE that the Secretary of State for the Environment in exercise of the powers conferred on him by Regulation 7(i) of the Water Authorities (Control of Outlets and Discharges) Regulations 1975 has reviewed the conditions previously imposed in a Consent deemed to be granted to the Southern Water Authority on 22nd February 1978 for the discharge of sewage effluent into the River Itchen

through an outlet

SU 4362 1484


at Grid Reference

and upon such review the Secretary of State has decided that the said conditions shall be varied in the manner and to the extent described in the Schedule hereto

DATED this 30th

day of July

1979

Signed 

SCHEDULE

Variation or revocation of conditions

The conditions of the consent dated the 22nd. February, 1978 are hereby revoked and the following conditions substituted therefor:-

Construction:

Use:

The outlet at Grid Reference SU 43621484 shall be used only for the discharge of treated sewage effluent.

Nature &
Composition:

The effluent discharged to the relevant waters shall comply with the following standard:-

- (a) Biochemical Oxygen Demand (Allylthiourea) in 5 days at 20°C not to exceed 35 mg/l
- (b) Suspended solids dried at 105°C not to exceed 80 mg/l

Volume or Rate
of Discharge:

The volume of effluent discharged under dry weather conditions shall not exceed 27,700 cubic metres in any period of 24 hours.

Sampling Point:

Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the cascade chamber indicated on the plan No. 409/102.