

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. 92


C84.

CAT. No. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
25th July 1961 (Varied 20th August 1979)	Whitbread Wessex Ltd., The Brewery, Romsey, Hants Potters Heron Hotel, Ampfield
N01016\1	
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
CONDITIONS IMPOSED WITH RESPECT TO:- (i) PRECISE LOCATION OF OUTLET SU 4110 2310 (ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) (iii) USE OF OUTLET The outlet at Grid Reference SU 4110 2310 shall be used only for the discharge of treated sewage effluent (iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	CONDITIONS IMPOSED WITH RESPECT TO:- (i) NATURE AND COMPOSITION OF DISCHARGE The effluent discharged to the relevant waters shall comply with the following standard: - (a) Biochemical Oxygen Demand (Allylthiourea) in 5 days at 20°C not to exceed 40 mg/l (b) Suspended solids dried at 105°C not to exceed 60 mg/l (ii) TEMPERATURE OF DISCHARGE (iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES The volume of effluent discharged under dry weather conditions shall not exceed 40 cubic metres in any period of 24 hours * (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the point of discharge to the watercourse * (v) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT 20th August 1981
REMARKS-	REMARKS-

NOTICE TO THE ENVIRONMENT AGENCY*

Environment Act 1995, Schedule 23, para 21(2)(b)(ii)



*The notes below may help in completing this notice.

WITH RESPECT TO THE FOLLOWING CONSENT [as given by the National Rivers Authority (or its predecessors)] WHICH WAS IN FORCE ON 31st MARCH 1996,

Name on former NRA Register on 31/3/96 The occupier

Consent Number 3041102310 92 Date consent was given 20.08.79

NO 1016 C82 or last reviewed

for the making of a discharge/several discharges of (G) Sewage

at Discharge Site Address PETERS TILTON HOTEL, AULFIELD, NR ROUSEY,

HANTS SO51 9ZF

I HEREBY GIVE NOTICE TO THE ENVIRONMENT AGENCY THAT I AM THE PERSON MAKING THE DISCHARGE(S) REFERRED TO ABOVE AND THAT I PROPOSE TO RELY ON this consent / the consents

as on the attached signed and dated list** Delete as appropriate

AFTER 1st OCTOBER 1996 AND WISH TO BE REGISTERED AS THE CONSENT HOLDER.

Name of Consent Holder ('the Discharger') WHITBREAD TILTON COMPANY

<If you are a body corporate please complete with the registered name/address of the body corporate - see note 2 below>

Address PETERS TILTON HOTEL, AULFIELD,

NR ROUSEY, HANTS Post Code SO51 9ZF

SIGNED [Signature] DATED 11th June 96

<job title GENERAL MANAGER>

<being the person with the delegated authority to sign of behalf of a body corporate - see note 2 below>

NOTES TO HELP YOU TO COMPLETE THIS NOTICE

1. If you are attaching a list of consents (as prepared by us from the NRA Register as on 31/3/96) then please overwrite the top section of this notice with the words 'Consents as on attached signed and dated list'. You should thoroughly check this list and modify and initial where necessary before signing and dating each page of the list and attaching to this completed notice. You may of course use your own list of consents you propose to rely on provided that the information above is included in full and each page is signed and dated.

2. In addition to an individual, a 'person' in legal terms may refer to a 'body corporate' (e.g. public limited company ('plc'), limited company, local authority etc.). In these cases the body corporate will be registered as the consent holder. The person signing on behalf of the body corporate will be the person who has the power to do so (usually the Company Secretary for a plc or limited company, the Chief Executive for a local authority etc). The legal validity of the signatory is the responsibility of the body corporate. If you are signing with the delegated authority of the body corporate, please indicate your job title.

3. Legal advice may be advisable for some situations (e.g. grant maintained schools outside of local authority control).

4. If you are a partnership or registered charity then up to 4 partners/trustees should individually complete this notice. These partners/trustees will then be registered as joint consent holders.

5. If you share the making of the discharge(s) with another person(s) then you should all complete the notice and be registered as joint consent holders. (e.g. householders individually and severally discharging via a common private sewage treatment works).

6. If in doubt, it may help to consider the 'person' as the person, either individually or severally, who would apply for the consent if an application were in future to be made to the Environment Agency. Under the amended legislation, ONLY the registered consent holder may in future apply to the Agency for a variation of the consent.

NOTE: The responsibility for this notice rests entirely with you and the Agency cannot be held responsible in any way for mistakes made as a result of the notes above (or otherwise) which are given in good faith.

NRA SOUTHERN REGION				
FOR ACTION				
14 JUN 1996				
FOR INFO				

C84

SOUTHERN WATER AUTHORITY

RIVERS (PREVENTION OF POLLUTION) ACTS 1951-1961

To : **Whitbread Wessex Ltd.,**
The Brewery,
Rousey,
Hants.

TAKE NOTICE that the Southern Water Authority in exercise of the powers conferred on them by Section 5(1) of the Rivers (Prevention of Pollution) Act, 1961 have reviewed the conditions previously imposed by the ~~former Hampshire River Board~~ in a consent granted to ~~Whitbread Wessex Ltd.~~ on the 25th July 1961 for

the discharge of ~~treated sewage effluent~~ through an outlet at Grid Reference **SU 4110 2310** and upon such review the Southern Water Authority have decided that the said conditions shall be varied in the manner and to the extent described in the Schedule hereto

The terms of this Notice will not without the consent in writing of the person to whom this consent is given (or his successor) be altered before the expiration of the period ending with the **20th** day of **August** 19**81**

DATED this **20th** day of **August** 1979

Signed

CHIEF SOLICITOR

Guildbourne House
Worthing
West Sussex
BN11 1LD

SCHEDULE

Variation or revocation of conditions

The conditions of the consent dated the **25th July 1961** are hereby revoked and the following conditions substituted therefor:-

- Use: The outlet at Grid Reference **SU 4110 2310** shall be used only for the discharge of **treated sewage effluent**
- Nature & Composition The effluent discharged to the relevant waters shall comply with the following standard:-
- (a) Biochemical Oxygen Demand (Allylthiourea) in 5 days at 20° C not to exceed **40** mg/l
 - (b) Suspended solids dried at 105° C not to exceed **60** mg/l
- Volume or Rate of Discharges: The volume of effluent discharged under dry weather conditions shall not exceed **40** cubic metres in any period of 24 hours.
- Sampling Point: Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the point ~~indicated on the plan of~~ **discharge to the watercourse**