



DEPARTMENT OF THE ENVIRONMENT

DOE FILE No. HMIP 29/10/538
COPA No. 11280

CONTROL OF POLLUTION ACT 1974 - SECTION 34
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES)
REGULATIONS 1984

CONSENT FOR A DISCHARGE

1. The ANGLIAN WATER AUTHORITY (hereinafter referred to as "the Water Authority") proposes to discharge sewage effluent in accordance with the application dated 30 November 1984, as supplemented on 5 December 1986.
2. The proposal requires the consent of the Secretary of State for the Environment in pursuance of section 34 of the Control of Pollution Act 1974 and the Control of Pollution (Discharges by Authorities) Regulations 1984.
3. The SECRETARY OF STATE FOR THE ENVIRONMENT hereby consents to the proposed discharge subject to the conditions set out in the schedule attached hereto.

Signed 
On behalf of the Secretary of
State for the Environment

Dated the 23 day
of December 1988

SCHEDULE

CONDITIONS PRESCRIBED FOR THE DISCHARGE OF SEWAGE EFFLUENT FROM ISLIP SEWAGE TREATMENT WORKS TO THE RIVER NENE.

A. NATURE OF EFFLUENT

1. The discharge shall consist of treated sewage effluent from an outlet at National Grid Reference SP 9938 7958 and settled storm sewage from an outlet at National Grid Reference SP 9938 7958.

B. VOLUME OF EFFLUENT

1. The volume of treated sewage effluent discharged under dry weather conditions shall not exceed 2400 cubic metres in any period of 24 hours.

2. The volume of settled storm sewage discharged to the receiving water shall be limited to that resulting from the overflow of sewage at the storm sewage separating weir of flows in excess of 55.56 litres per second and shall only be made when, and only for as long as, the storm tanks are full. The storm tanks shall be emptied and their contents returned to the flow for full treatment as soon as practicable after cessation of the overflow from the tanks.

C. COMPOSITION OF EFFLUENT

1. In any series of samples of the treated effluent taken over any period of one year as listed in column 1 of the table set out in the annex to this schedule, no more than the relevant number of samples as permitted in column 2 of the said table shall contain:

a. in excess of 60 milligrams per litre of suspended solids (measured after drying at 105 degrees Celsius) .

b. in excess of 40 milligrams per litre of biochemical oxygen demand (determined in the presence of 0.5 milligrams per litre of allyl-thiourea after 5 days at 20 degrees Celsius) .

2. The composition of the settled storm sewage shall be such that suspended solids (measured after drying at 105 degrees Celsius) shall not exceed 200 milligrams per litre.

Handwritten signature
23.12.88



DEPARTMENT OF THE ENVIRONMENT

DOE File No. HMIP 29/10/538

CONTROL OF POLLUTION ACT 1974 - SECTION 37
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES)
REGULATIONS 1984

REVOCATION OF A CONSENT

NOTICE is hereby given to the ANGLIAN WATER AUTHORITY (hereinafter referred to as "the Water Authority") that the consent dated 15 June 1971 (and any subsequent variations) granted to the Oundle and Thrapston Rural District Council in pursuance of the Rivers (Prevention of Pollution) Acts 1951 and 1961 to discharge effluent from the Water Authority's Islip sewage disposal works and Thrapston, Denford and Ringstead sewage pumping stations to The River Nene, The Delph, (a tributary of the River Nene) and a culverted tributary of the River Nene (which consent has effect, by virtue of regulation 3 of the Control of Pollution (Consents: Transitional Provisions) Regulations 1985 (S.I. 1985 No 5) , as if given in pursuance of Section 34(2) of the Control of Pollution Act 1974) is revoked with effect from the date of this notice.

Signed 
On behalf of the Secretary of
State for the Environment

Dated the 23 day
of December 1988

D. TAKING OF SAMPLES

1. The Water Authority shall take samples of the treated sewage effluent in accordance with the relevant provisions of the Water Authority's sampling guidelines for the time being in force and approved for this purpose by the Secretary of State and shall keep records of such samples and the results of the analyses thereof for inspection by the Secretary of State's authorised representatives.

2. Facilities shall be provided to the Secretary of State's representatives so as to enable samples of the effluent to be conveniently obtained.

E. RENDERING OF REPORTS

1. The Water Authority shall, within 2 months of the end of each calendar year, notify the Department if any of the composition limits in condition C1 above have been exceeded and of the steps which have been taken or which it is proposed to take in consequence.

Signed *A. S. Lawrence*
On behalf of the Secretary of
State for the Environment

Dated the 23 day
of December 1988

TABLE

(1)	(2)
Series of samples taken in any year	Maximum permitted number of samples with fail to conform to numerical limits
4-7	1
8-16	2
17-28	3
29-40	4
41-53	5
54-67	6
68-81	7
82-95	8
96-110	9
111-125	10
126-140	11
141-155	12
156-171	13
172-187	14
188-203	15
204-219	16
220-235	17
236-251	18
252-268	19
269-284	20
285-300	21
301-317	22
318-334	23
335-350	24
351-365	25