

## Water Quality Public Register Scanning

### PERMIT REFERENCE (EDRM OTHER REFERENCE)

Permit Reference as it appears on the permit including characters (/.-)

N/WR 1186

CANM 1186



**ENVIRONMENT  
AGENCY**

## **Consent to Discharge**

Water Resources Act 1991 (as amended by the Environment Act 1995)

**Consent Holder(s)**



**Company Secretary  
Iver Recycling Ltd  
Unit 6  
Court Lane Industrial Estate  
Iver  
Buckinghamshire  
SL0 9HL**

**Consent to Discharge from**

**Iver Recycling Ltd  
Unit 6  
Court Lane Industrial Estate  
Iver  
Buckinghamshire  
SL0 9HL**

**Consent Number**

**NWR1186**

**Environment Agency Thames Region**

**Apollo Court, 2 Bishops Square Business Park, St Albans Road West, Hatfield, Herts AL10 9EX**

**Tel: 08708 506506 Fax: 01707 632500**

**Consent to Discharge**

Water Resources Act 1991  
Section 88, Schedule 10  
(as amended by the  
Environment Act 1995)



**ENVIRONMENT  
AGENCY**

## Consent to Discharge

Consent Number  
**N/WR1186**

To:  
[REDACTED] ("the Consent Holder")  
Company Secretary  
**Iver Recycling Ltd**  
Unit 6  
Court Lane Industrial Estate  
Iver  
Buckinghamshire  
SL0 9HL

The Environment Agency ("the Agency") in pursuance of its powers under the Water Resources Act 1991 (as amended by the Environment Act 1995) hereby consents to the making of a discharge:

Of:  
1 **Secondary treated sewage effluent ("the Discharge")**  
2 **Trade effluent comprising of site drainage ("the Discharge")**

From:  
**The sewage treatment plant and an oil interceptor from a commercial property.**

At:  
**Iver Recycling Ltd, Unit 6, Court Lane Industrial Estate, Iver,  
Buckinghamshire SL0 9HL**

To:  
**Grand Union Canal**

Subject to the conditions set out in this notice of Consent to Discharge.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991 (as amended by the Environment Act 1995), no notice shall be served by the Agency, altering this consent, without the agreement of the Consent Holder, during a period of 4 years from the date this notice is issued.

This Consent is issued on:

**22 FEB 2007**

This Consent takes effect on:

**22 FEB 2007**

Signed

[REDACTED SIGNATURE]

**Team Leader Regulatory Water Quality**

1 **Conditions of Consent for secondary treated sewage effluent**

1.1 **Nature**

1.1.1 The Discharge shall consist solely of secondary treated sewage effluent.

1.2 **Place of Discharge**

1.2.1 The Discharge shall be made in the manner and at the place specified as:

- a discharging to Grand Union Canal;
- b at National Grid Reference TQ 04430 80596;
- c shown marked "A/OUTLET" on Site Plan attached to this consent.

1.3 **Sampling Point Requirements**

1.3.1 A sample point shall be provided and maintained at National Grid Reference TQ 04189 80409 as shown marked "B/SAMPLE POINT" on the Site Plan attached to this consent, so that a representative sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

1.4 **Volume**

1.4.1 The volume of the Discharge shall not exceed 2 cubic metres per day.

1.5 **Composition**

1.5.1 As far as is reasonably practicable, the sewage treatment plant shall be operated so as to prevent the Discharge from containing any significant trace of visible oil or grease.

1.6 **Priority Substances**

1.6.1

- a The quantity of Copper or Zinc in the Discharge shall not increase above the levels in the Discharge on the date of effect of this consent where no specific level is authorised; and
- b notwithstanding a above, the Discharge shall not contain quantities of Copper or Zinc such as to cause or contribute to the concentration of that substance in the receiving water exceeding the relevant Environmental Quality Standard (EQS).

**1.7 Works Operation**

**1.7.1**

The sewage treatment plant shall be operated and the effluent shall be treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the Discharge made from the sewage treatment plant on controlled waters.

**1.8 Maintenance**

**1.8.1**

The sewage treatment plant shall be operated and maintained in accordance with good operational practice such that:

- a** it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
- b** following a failure all equipment shall be returned to normal operation as soon as practicable;
- c** tanks shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.

**1.9 Recording and Reporting**

**1.9.1**

- a** The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- b** On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality
- c** The Consent Holder shall as soon as reasonably practicable report to the Agency all non-routine actions that may have adversely affected effluent quality.

2 **Conditions of Consent for trade effluent consisting of site drainage**

2.1 **Nature**

2.1.1 The Discharge shall consist solely of trade effluent consisting of site drainage.

2.2 **Place of Discharge**

2.2.1

The Discharge shall be made in the manner and at the place specified as:

- a discharging to the Grand Union Canal;
- b at National Grid Reference TQ 04430 80596;
- c shown marked "A/OUTLET" on Site Plan attached to this consent.

2.3 **Sampling Point Requirements**

2.3.1

The outlet to controlled waters shall be constructed and maintained so that a representative sample of the Discharge may be obtained at National Grid Reference TQ 04430 80596 as shown marked "A/OUTLET" on the Site plan attached to this consent.

2.4 **Composition**

2.4.1

The Discharge shall not contain more than 100 milligrammes per litre of suspended solids (measured after drying at 105°C).

2.4.2

As far as is reasonably practicable, the plant shall be operated so as to prevent the Discharge from containing any significant trace of visible oil or grease.

2.5 **Works Operation**

2.5.1

- a The plant shall be operated and the effluent treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the Discharge on controlled waters.
- b This condition does not require any alteration of the type of treatment used from that specified in the application.

2.6 **Maintenance**

2.6.1

The plant shall be operated and maintained in accordance with good operational practice such that:

- a it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
- b following a failure all equipment shall be returned to normal operation as soon as practicable;
- c it shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.



2.7

**Recording and Reporting**

2.7.1

- a** The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- b** On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality
- c** The Consent Holder shall as soon as reasonably practicable report to the Agency all non-routine actions that may have adversely affected effluent quality.

# Site plan



This map is reproduced from the OS map by the Environment Agency with the permission of the Controller of Her Majesty's Stationery Office, Crown copyright. Unauthorised reproduction infringes Crown Copyright and may lead to prosecution or civil proceedings: Licence Number GD 03177G