

ENVIRONMENT AGENCY, SOUTH WEST REGION

NOTICE OF MODIFICATION TO CONSENT

**Water Resources Act 1991 Section 88 and Schedule 10
(As amended by the Environment Act 1995)**

Nature of discharge: Treated sewage effluent.
Site Name: Rode Sewage treatment Works.
Authorised by consent reference: 011560.
Issued by: National Rivers Authority.
Issued on: 01/06/1990

The Environment Agency in pursuance of its powers under the Water Resources Act 1991 Schedule 10 has reviewed the consent identified above and has determined that the conditions of that consent shall be modified as follows:

Delete condition: 9

The discharge of settled sewage shall not:

(a) have a biochemical oxygen demand (nitrification suppressed) over 5 days at 20 °C in excess of 200 mg/l,

(b) contain suspended solids (dried at 105 °C) in excess of 200 mg/l.

Delete condition: 11

At the written request of the Authority the discharger shall install and maintain suitable flow measuring and recording devices to measure the volume and rate of flow of sewage to full treatment and to storm discharges and the flow at which any storm discharge commences operation. The discharger shall make returns of the information to the Authority at the frequency and in the form and manner requested. The discharger shall also make available to the Authority any other flow records which are held. Flow measuring devices shall be accessible at all times without delay to the Authority's representatives. Facilities shall be provided to enable the Authority to install flow measuring equipment as required.

Replace National Grid References:

Point A: ST 8043 5456 with:

Point A - Final Effluent Discharge Point: ST 8041 5456

Point B: ST 8042 5455 with:

Point C - Storm Effluent Discharge Point: ST 8040 5455

Point 1: ST 8043 5456 with:

Point B - Final Effluent Sampling Point: ST 8042 5456

Point 2: ST 8041 5453 with: