REGISTER OF CONSENTS

UN[redacted] SECTION 72 OF THE WATER RESOURCES ACT 1[redacted]

NC3060

CAT. No. R.A.13. SHAW & SONS LTD.

PERSON TO WHOM CONSENT WAS GRANTED	DETAILS AND LOCATION OF DISCHARGE	DATE OF APPLICATION	WHEN CONSIDERED BY COMMITTEE	DATE OF GRANT OF CONSENT	CONSENT NO.	INDEX REFERENCE
D. Jones, Esq., The Coach House, The Old Rectory, Twineham, Sussex.	Septic Tank - The Coach House, The Old Rectory, Twineham, Sussex. TQ2540 1988	14th August 1978		23rd May 1979	WR/191/182	

AGENT -

VARIATION OR REVOCATION OF CONSENT IN PURSUANCE OF AN APPLICATION OR OTHERWISE

GRANT OR VARIATION OF CONSENT IN ACCORDANCE WITH DIRECTION GIVEN BY MINISTER ON APPEAL

CONDITIONS ATTACHED TO CONSENT

(a) The outlet at National Grid Reference TQ 25401988 shall be used only for the discharge of septic tank effluent.

(b) The volume of the effluent discharged under dry weather conditions shall not exceed 1 cubic metre in any period of 24 hours.

(c) Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the point indicated on the un-numbered plan submitted with the application.

(d) The effluent shall be discharged to underground strata by means of pipes, the maximum depth below ground level of which shall not exceed 1 metre, via a minimum of 55 metres of soakaway drain, as indicated on the un-numbered plan submitted with the application.

(e) The tank should be emptied at least once per annum.

TQ2514