Notice of variation and consolidation with introductory note

The Environmental Permitting (England & Wales) Regulations 2016

Severn Trent Water Limited

Blymhill Sewage Treatment Works
Brineton
Shifnal
Staffordshire
TF11 8NN

Variation number

S/04/55801/R/V003

Permit number

S/04/55801/R

Blymhill Sewage Treatment Works
Permit number S/04/55801/R

Introductory note

This introductory note does not form a part of the notice.

Under the Environmental Permitting (England & Wales) Regulations 2016 (schedule 5, part 1, paragraph 19) a variation may comprise a consolidated permit reflecting the variations and a notice specifying the variations included in that consolidated permit.

Schedule 1 of the notice specifies the conditions that have been varied and schedule 2 comprises a consolidated permit which reflects the variations being made. Only the variations specified in schedule 1 are subject to a right of appeal.

There is a Water Framework Directive (WFD) requirement to improve the status of Meese - Aqualate Mere tributaries from a phosphorus (P) perspective within water body GB109054050190 (Meese - Aqualate Mere tributaries). Catchment P modelling indicated that the required WFD P standard within AMP7 would be a 12 month rolling mean limit of 1 mg/l, (as confirmed by WINEP, Water Industry National Environment Programme). Performance at this level will allow Meese - Aqualate Mere tributaries to progress to achieving 'good' WFD status from 22nd December 2024. Blymhill Lane Sewage Treatment Works (STW) does not have any previous requirements for P removal. River water quality modelling has indicated that the required two-tier limits for total iron of 4,000 µg/l Look Up Table and 8,000 µg/l Upper Tier provides adequate protection to the receiving watercourse.

The status log of a permit sets out the permitting history, including any changes to the permit reference number.

Status log of the permit		
Description	**Date**	**Comments**
Permit S/04/55801/R	17/03/2004	Permit renumbered from S/04/22029/R and S/04/50106/R. Permit issued to Severn Trent Water Limited.
Permit modified S/04/55801/R	30/11/2005	Modification to add the following conditions: dangerous substances, investigate and Monitor and operational surveillance.
Permit modified S/04/55801/R	14/10/2008	Modification to incorporate Operator Self Monitoring (OSM) requirements.
Permit modified S/04/55801/R	30/03/2010	Notice of modification to substitute Dry Weather Flow and flow measurement conditions.
Environment Agency initiated variation S/04/55801/R/V002	20/10/2020	Variation to incorporate the DWF 3 in 5 year and data quality conditions.
Variation determined S/04/55801/R	06/01/2021	Varied and consolidated permit issued in modern condition format.
Environment Agency initiated variation S/04/55801/R/V003	09/05/2024	Variation of permit initiated under PR19 review programme to incorporate improvements to be delivered under AMP7.
Variation determined S/04/55801/R	24/05/2024	Varied and consolidated permit issued in modern condition format.

End of introductory note

Notice of variation and consolidation

The Environmental Permitting (England and Wales) Regulations 2016

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2016 varies and consolidates

Permit number

S/04/55801/R

Issued to

Severn Trent Water Limited ("the operator")

whose registered office is

Severn Trent Centre
2 St John's Street
Coventry
CV1 2LZ

company registration number **02366686**

to operate a water discharge activity at

Blymhill Sewage Treatment Works
Brineton
Shifnal
Staffordshire
TF11 8NN

to the extent set out in the schedules.

The notice shall take effect from 24/05/2024

Name	Date
Cameron Mills	**24/05/2024**

Authorised on behalf of the Environment Agency

Schedule 1

Only conditions 3.1.5, 3.1.6, Table S3.1a, Table S3.1b, Table S3.2, Table S3.3, Schedule 3D, Table S4.1, Table S4.2, Schedule 5, Schedule 6and Schedule 7 have been varied by the consolidated permit S/04/55801/R as a result of an Environment Agency initiated variation.

Schedule 2 – consolidated permit

Consolidated permit issued as a separate document.

Permit

The Environmental Permitting (England and Wales) Regulations 2016

Permit number

S/04/55801/R

This is the consolidated permit referred to in the variation and consolidation notice for variation **S/04/55801/R/V003** authorising,

Severn Trent Water Limited ("the operator"),

whose registered office is

Severn Trent Centre
2 St John's Street
Coventry
CV1 2LZ

company registration number **02366686**

to operate a water discharge activity at

Blymhill Sewage Treatment Works
Brineton
Shifnal
Staffordshire
TF11 8NN

to the extent authorised by and subject to the conditions of this permit.

Name	Date
Cameron Mills	**24/05/2024**

Authorised on behalf of the Environment Agency

Conditions

1 Management

1.1 General management

1.1.1 The operator shall manage and operate the activity:

(a) in accordance with a written management system that identifies and minimises risks of pollution so far as is reasonably practicable, including those risks arising from operations, maintenance, accidents, incidents, non-conformances and those drawn to the attention of the operator as a result of complaints; and

(b) using sufficient competent persons and resources.

1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.

1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of the permit.

2 Operations

2.1 Permitted activities

2.1.1 The only activity authorised by the permit is the activity specified in schedule 1 table S1.1.

2.2 The site

2.2.1 The discharge activity shall take place at the discharge point marked on the site plan at schedule 7 to this permit, and as listed in table S3.2; and, the operating technique that is the subject of conditions prefixed by 2.3 shall be applied at the locations shown, or otherwise described, in schedule 7.

2.3 Operating techniques

2.3.1 For the activity referenced in schedule 1, table S1.1 the operator shall comply with the relevant requirements of the Urban Waste Water Treatment (England and Wales) Regulations 1994.

3 Emissions and monitoring

3.1 Emissions to water

3.1.1 The limits given in schedule 3 table S3.1 shall not be exceeded.

3.1.2 The limits in schedule 3 table S3.1 to which this condition applies may be exceeded where: in any series of samples of the discharge taken at regular but randomised intervals in any period of twelve consecutive months as listed in column 1 of schedule 3A, no more than the relevant number of samples, as listed in column 2 of schedule 3A, exceed the applicable limit for that relevant parameter.

3.1.3

(a) For the emission limits in schedule 3 table S3.1 to which this condition applies, no sample of the discharge taken at a time when unusual weather conditions are adversely affecting the

operation of the waste water treatment works, shall be taken into account in deciding whether or not the emission limit has been complied with.

(b) On any occasion where unusual weather conditions adversely affect the operation of the waste water treatment works, the operator shall use its best endeavours to mitigate that adverse effect.

(c) For any sample of the discharge taken to be considered for the purposes of (a) above, the operator shall notify the Environment Agency in writing within 14 days of becoming aware that an emission limit has been exceeded. That notification shall include a full description of the unusual weather conditions and their impact on the operation of the works.

3.1.4 The permitted Dry Weather Flow limit in schedule 3 table S3.1 is set at the operator's planned annual 80% exceeded daily volume discharged.

(a) For compliance purposes an exceedance shall be recorded for a calendar year only when the limit in effect on 31 December of that calendar year is exceeded by 90% or more of the 'good' recorded Total Daily Volumes in that calendar year.

(b) Up to and including 31 December 2025:

(i) If an exceedance of the Dry Weather Flow limit is recorded in a calendar year then the operator shall, as soon as is reasonably practicable, investigate the reasons for the exceedance.

(ii) The operator shall report the reasons for the exceedance to the Environment Agency and the steps that it proposes to take to restore compliance.

(iii) An exceedance of the Dry Weather Flow limit shall not be recorded as a failure of the Dry Weather Flow limit in that calendar year if the operator takes appropriate steps to restore compliance.

(c) From the 1 January 2026 the limit has been complied with in an assessment calendar year unless;

(i) the limit was exceeded in the compliance assessment calendar year, and;

(ii) two or more exceedances have occurred in the preceding 4 calendar years.

3.1.5 The limits in schedule 3 table S3.1 to which this condition applies are assessed using any series of samples of the discharge taken at regular but randomised intervals in any period of twelve consecutive months.

3.1.6 The emission limits in schedule 3 table S3.1 to which this condition applies shall have been complied with if the lower bound 90% confidence interval calculated in accordance with schedule 3D is less than or equal to that emission limit.

3.2 Emissions of substances not controlled by emission limits

3.2.1 The operator shall take appropriate measures to minimise so far as reasonably practicable the polluting effects of the emissions of substances in the discharge not controlled by emission limits (excluding odour).

3.3 Monitoring

3.3.1 The operator shall, unless otherwise agreed in writing by the Environment Agency, undertake the monitoring specified in the following tables in schedule 3 to this permit:

(a) point source emissions specified in tables S3.1 and S3.3;

3.3.2 The operator shall maintain records of all monitoring required by this permit.

3.3.3 Monitoring equipment, techniques, personnel and organisations employed for the emissions monitoring programme specified in condition 3.3.1 shall have either MCERTS certification or MCERTS accreditation (as appropriate), where available, unless otherwise agreed in writing by the Environment Agency.

3.3.4 An accessible monitoring point shall be provided and maintained to enable the emissions monitoring programme and/or other monitoring to be carried out at the monitoring points specified in table S3.3 of schedule 3 and shown marked on the site plan in schedule 7.

3.3.5 The monitoring programme for the parameters subject to schedule 3B shall be:

(a) pre-scheduled to cover a calendar year and the programme recorded before the start of a calendar year sample period; and

(b) spot samples collected at approximately equal intervals during the year, including samples from different days of the week and different times. Approximately 10% of samples should be outside the normal sampling window which is 9am-3pm, Monday to Friday.

3.3.6 After becoming aware, or following a notification that a sample has not been taken on the schedule 3B Monitoring Programme pre-scheduled date, or is lost, or a result for that sample cannot be reported, the operator shall record the details and reschedule the sample.

3.3.7

(a) Total Daily volumes shall be calculated from the average of the available ‘good’ 15 minute flow readings taken from midnight to midnight where;

Total Daily Volume (m3) = {Sum of ‘good’ readings (l/s) / number of ‘good’ readings} x {86,400 (s) / 1000}.

Where there are 87 or more ‘good’ 15 minute flow readings the Total Daily Volume shall be reported as ‘good’, where there are 1 – 86 ‘good’ readings it shall be reported as ‘suspect’ and where there are no ‘good’ readings as ‘missing’.

(b) The operator shall record all failures of the flow measurement system and any other breaks in the flow record and the reasons for all issues, failures and breaks that lead to missing or suspect Total Daily Volume records and all steps taken to prevent a re-occurrence.

(c) There shall be no more than 37 days and/or no more than 14 consecutive days with ‘suspect’ or ‘missing’ Total Daily Volumes in a calendar year, unless otherwise agreed in writing by the Environment Agency.

(d) All 15 minute flow readings shall be flagged as ‘good’, ‘suspect’ or ‘missing’ using an appropriate methodology set out in the operator’s flow monitoring quality management system.

4 Information

4.1 Records

4.1.1 All records required to be made by schedule 3, 4 and 5 to this permit shall:

(a) be legible;

(b) be made as soon as reasonably practicable;

(c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and

(d) be retained, unless otherwise agreed in writing by the Environment Agency, for at least 6 years from the date when the records were made.

4.1.2 The operator shall maintain convenient access, in either electronic or hard copy, to the records, plan and management system required to be maintained by this permit.

4.2 Reporting

4.2.1 The operator shall send all reports and notifications required by the permit to the Environment Agency using the contact details supplied in writing by the Environment Agency.

4.2.2 Within the time period after the end of the reporting period specified in schedule 4 table S4.1 the operator shall, unless otherwise agreed in writing by the Environment Agency, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:

(a) in respect of the parameters and monitoring points specified in schedule 4 table S4.1;

(b) for the reporting periods specified in schedule 4 table S4.1 and using the forms specified in schedule 4 table S4.2; and

(c) giving the information from such results and assessments as may be required by the forms specified in those tables.

4.3 Notifications

4.3.1 The Environment Agency shall be notified as soon as reasonably practicable following detection, within the site of the regulated facility of:

(a) any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution; and

(b) any breach of a limit specified in schedule 3 table S3.1 (including individual exceedances of limits which are covered by condition 3.1.2).

Any other significant adverse environmental effects, which may have been caused by the activity, shall also be notified to the Environment Agency as soon as reasonably practicable following detection.

4.3.2 The information provided under condition 4.3.1 shall be supported by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.

4.3.3 Where the Environment Agency has requested in writing that it shall be notified when the operator is to undertake monitoring and/or spot sampling specified in schedule 3B, the operator shall inform the Environment Agency when the relevant monitoring and/or spot sampling is to take place. The operator shall provide this information to the Environment Agency at least 14 days before the date the monitoring is to be undertaken.

4.3.4 The Environment Agency shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:

Where the operator is a registered company:

(a) any change in the operator's trading name, registered name or registered office address; and

(b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.

Where the operator is a corporate body other than a registered company:

(a) any change in the operator's name or address; and

(b) any steps taken with a view to the dissolution of the operator.

4.3.5 Where the operator proposes to make a change in the nature of the activity by increasing the concentration of, or the addition of, or allowing the introduction of, a substance to the activity to an

extent that the operator considers could have a significant adverse environmental effect on the receiving waters, and the change is not permitted by emission limits specified within schedule 3 table S3.1 or the subject of an application for approval under the EP Regulations or under the terms of this permit:

(a) the Environment Agency shall be notified in writing at least 14 days before the increase or addition or allowing the introduction; and

(b) the notification shall contain a description of the proposed change.

4.3.6 For the activity referenced in schedule 1, table S1.1 the operator shall inform the Environment Agency in writing of any change, or proposed change, to the population equivalent such as would make a material change to the application of the Urban Waste Water Treatment (England and Wales) Regulations 1994 and shall, on request, inform the Environment Agency in writing of the actual population equivalent.

4.4 Interpretation

4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.

4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made “as soon as reasonably practicable”, in which case it may be provided by telephone.

Schedule 1 – Operations

Table S1.1 Activities	
Description of activity	**Limits of specified activity**
Discharge of secondary treated sewage effluent via Final Effluent Outfall	N/A

Schedule 2 – Waste types, raw materials and fuels

Schedule 2 not in use.

Schedule 3 – Emissions and monitoring

Table S3.1a Point Source emissions to water (other than sewer) – emission limits and monitoring requirements **Effective up to and including 21st December 2024**						
Effluent(s) and discharge point(s)	**Parameter**	**Limit (including unit)**	**Reference Period**	**Limit of effective range**	**Monitoring frequency**	**Compliance Statistic**
Secondary treated sewage effluent via Final Effluent Outfall	Dry weather flow	223 m^3/day	Total daily volume	N/A	Continuous	Condition 3.1.4 applies
	15-minute instantaneous or averaged flow	No limit set. Record as l/s	15 minute	N/A	Continuous	N/A
	ATU-BOD as O_2	15 mg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Ammoniacal nitrogen (expressed as N)	5 mg/l	Instantaneous (spot sample)	1 May to 31 October inclusive	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Ammoniacal nitrogen (expressed as N)	10 mg/l	Instantaneous (spot sample)	1 November to 30 April inclusive	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Suspended solids (measured after drying at 105°C)	25 mg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Total iron as Fe	4,000 µg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Total iron as Fe	8,000 µg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Maximum (Condition 3.1.3 applies)
	Visible oil or grease	No significant trace present so far as is reasonably practicable	Instantaneous (visual examination)	N/A	N/A	No significant trace (Condition 3.1.3 applies)

Table S3.1b Point Source emissions to water (other than sewer) – emission limits and monitoring requirements Effective from 22nd December 2024						
Effluent(s) and discharge point(s)	**Parameter**	**Limit (including unit)**	**Reference Period**	**Limit of effective range**	**Monitoring frequency**	**Compliance Statistic**
Secondary treated sewage effluent via Final Effluent Outfall	Dry weather flow	223 m^3/day	Total daily volume	N/A	Continuous	Condition 3.1.4 applies
	15-minute instantaneous or averaged flow	No limit set. Record as l/s	15 minute	N/A	Continuous	N/A
	ATU-BOD as O_2	15 mg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Ammoniacal nitrogen (expressed as N)	5 mg/l	Instantaneous (spot sample)	1 May to 31 October inclusive	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Ammoniacal nitrogen (expressed as N)	10 mg/l	Instantaneous (spot sample)	1 November to 30 April inclusive	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Suspended solids (measured after drying at 105°C)	25 mg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Total phosphorus as P	1 mg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Rolling 12 month mean (Conditions 3.1.3, 3.1.5, 3.1.6 and schedule 3D apply)
	Total iron as Fe	4,000 µg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Look up table (Conditions 3.1.2 and 3.1.3 apply)
	Total iron as Fe	8,000 µg/l	Instantaneous (spot sample)	N/A	As specified in schedule 3B	Maximum (Condition 3.1.3 applies)

Table S3.1b Point Source emissions to water (other than sewer) – emission limits and monitoring requirements Effective from 22nd December 2024						
Effluent(s) and discharge point(s)	**Parameter**	**Limit (including unit)**	**Reference Period**	**Limit of effective range**	**Monitoring frequency**	**Compliance Statistic**
	Visible oil or grease	No significant trace present so far as is reasonably practicable	Instantaneous (visual examination)	N/A	N/A	No significant trace (Condition 3.1.3 applies)

Table S3.2 Discharge points			
Effluent Name	**Discharge Point**	**Discharge point NGR**	**Receiving water/Environment**
Secondary treated sewage effluent	Final Effluent Outfall	SJ 80425 13615	Tributary of Wyndford Brook

Table S3.3 Monitoring points			
Effluent(s) and discharge point(s)	**Monitoring type**	**Monitoring point NGR**	**Monitoring point reference**
Secondary treated sewage effluent via Final Effluent Outfall	Effluent sampling	SJ 80427 13615	OSM Final Effluent Sampling Point Monitoring point to be appropriately labelled.
	MCERTS flow monitoring	SJ 80462 13592	MCERTs flow monitoring point Monitoring point to be appropriately labelled.

Schedule 3A - Look up table

Look up table	
Number of samples taken in any period of 12 months	**Maximum number of samples permitted to exceed limit for given parameter**
4–7	1
8–16	2
17–28	3
29–40	4
41–53	5
54–67	6
68–81	7
82–95	8
96–110	9
111–125	10
126–140	11
141–155	12
156–171	13
172–187	14
188–203	15
204–219	16
220–235	17
236–251	18
252–268	19
269–284	20
285–300	21
301–317	22
318–334	23
335–350	24
351–365	25

Schedule 3B - OSM tier 3 sampling frequency

Parameter	'Normal frequency' of samples per year	Reduced Sampling frequency after 12 consecutive months of numeric permit compliance, samples per year or pro rata over the remainder of a year	On numeric limit failure return to normal frequency as soon as reasonably practicable, samples per 12 months	Out of hours samples
Sanitary	24	12	24	For 24 samples 2 out of hours samples per annum
Non sanitary	12	12	12	For 12 samples 1 out of hours sample per annum

Schedule 3C not in use

Schedule 3D – Rolling 12 month mean assessment methodology and t-values

Rolling 12 month mean compliance assessment method for site specific phosphorus limits (not UWWTR)

Use concentrations from the pre-scheduled samples taken in any period of 12 consecutive months unless a fixed 12-month period is specified by the permit.

1. Take the log10 value of all P concentrations in the data set. For a zero value, take the log10 value of the minimum detection limit of the analytical method used. Treat less thans or greater thans as face value.
2. Calculate the mean of the log10 values.
3. Calculate the standard deviation of the log10 values.
4. Calculate the lower confidence interval using the formula lower confidence interval = mean – (t x standard error of mean).

   Where:

   - t is derived from the values of t table for n-1 degrees of freedom, where n is the number of samples
   - the standard error of the mean is the standard deviation of the dataset ÷ √n.
5. Antilog the lower confidence interval.

If the lower bound confidence interval exceeds the permit limit, then we are 95% confident that the limit has been exceeded and a failure is recorded.

Values of t	
Degrees of freedom	**t for 90% confidence interval**
2	2.920
3	2.353
4	2.132
5	2.015
6	1.943
7	1.895
8	1.860
9	1.833
10	1.813
11	1.796
12	1.782
13	1.771
14	1.761
15	1.753
16	1.746
17	1.740
18	1.734

Values of t	
Degrees of freedom	**t for 90% confidence interval**
19	1.729
20	1.725
25	1.708
30	1.697
35	1.690
40	1.684
50	1.676
60	1.671
70	1.667
80	1.664
90	1.662
100	1.660
1,000	1.646

Schedule 4 – Reporting

Parameters, for which reports shall be made, in accordance with conditions of this permit, are listed below.

Table S4.1 Reporting of monitoring data			
Parameter	**Monitoring point reference**	**Reporting period**	**Period begins**
Dry Weather Flow (daily flows total)	MCERTs flow monitoring point	Annually Report to be submitted within 2 months of the end of the calendar year	1st January
15-minute flow	MCERTs flow monitoring point	Reports to be provided to the Environment Agency upon request Report to be submitted within 28 days unless otherwise specified in writing by the Environment Agency	Upon request by the Environment Agency
Operator Self Monitoring - ATU-BOD as O_2, ammoniacal nitrogen (expressed as N), suspended solids (measured after drying at 105°C), total phosphorus as P (effective from 22nd December 2024), total iron as Fe	OSM Final Effluent Sampling Point	Quarterly Report to be submitted within 28 days	1st of month
Operator Self Monitoring summary report	OSM Final Effluent Sampling Point	Annually Report to be submitted within 2 months of the end of the calendar year	1st January

Table S4.2 Reporting forms	
Parameter	**Reporting format**
Dry Weather Flow (daily flows total)	WISKI electronic format specified by the Environment Agency
15-minute flow	WISKI electronic format specified by the Environment Agency
OSM - ATU-BOD as O_2, ammoniacal nitrogen (expressed as N), suspended solids (measured after drying at 105°C), total phosphorus as P (effective from 22nd December 2024), total iron as Fe	Quarterly - Electronic format specified by the Environment Agency
Operator Self Monitoring summary report	Annually - Summary report of compliance with the monitoring programme specified in table S3.1 and schedule 3B in a format specified by the Environment Agency

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	
Name of operator	
Location of Facility	
Time and date of the detection	

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection unless otherwise agreed in writing by the Environment Agency	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released/type or nature of sewage released	
Best estimate of the quantity or rate of release of substances and/or duration of discharge	
Best estimate of the environmental impact of the discharge	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a limit specified in schedule 3 table S3.1 (including individual exceedances of limits which are covered by condition 3.1.2)	
The information specified below is to be notified to the Environment Agency as soon as reasonably practicable following detection.	
Monitoring point reference/ source	
Self monitoring regime (where relevant)	e.g. OSM
Type of failure	e.g. LUT failure/LUT exceedance/upper tier/other
Date of sample/event	
Parameter	
Result and units	
Limit and units	

Part B – to be submitted as soon as reasonably practicable unless otherwise agreed in writing by the Environment Agency

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident/breach/exceedance	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	

Name*	
Post	
Signature	
Date	

* authorised to sign on behalf of the operator

Schedule 6 – Interpretation

“accident” means an accident that may result in pollution.

"annually" means once every year.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“appropriate measures” for the purposes of the emission of substances not controlled by emission limits condition (condition 3.2.1) do not require the operator to undertake treatment to a level beyond that specified in schedule 1 table S1.1, or to carry out routine monitoring for substances not controlled by emission limits.

“ATU-BOD as O_2” means the biochemical oxygen demand (measured after 5 days at 20^{o}C with nitrification suppressed by the addition of allylthiourea).

“emissions of substances not controlled by emission limits” means emissions of substances to air, water or land from the permitted activities, which are not controlled by an emission limit.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2016 No.1154 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“MCERTS” means the Environment Agency’s Monitoring Certification Scheme.

"quarter" means a calendar year quarter commencing on 1 January, 1 April, 1 July or 1 October.

“sanitary parameters for OSM sampling” means ATU-BOD as O_2, Ammoniacal nitrogen (expressed as N), Suspended solids (measured after drying at 105^{o}C) and COD as O_2.

“significant pollution” means a category 1 or category 2 incident indicated by the Common Incident Classification Scheme (CICS).

“unusual weather conditions” includes, but is not limited to:

- low ambient temperatures, or the freezing of mechanical equipment in the works;
- significant snow deposits;
- tidal or fluvial flooding;
- weather conditions causing unforeseen loss of power supply to the sewage treatment that could not be ameliorated by the reasonable provision and operation of standby generation facilities.

“Urban Waste Water Treatment (England and Wales) Regulations 1994 (UWWTR)” means Urban Waste Water Treatment (England and Wales) Regulations 1994 SI 2841and the words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“year” means calendar year ending 31 December.

Schedule 7 – Site plan



END OF PERMIT