
Water Quality Public Register Scanning – Work Instruction
Appendix 1

PERMIT REFERENCE:
(EDRM OTHER REFERENCE)

Permit Reference as it appears on the permit including characters (/.-\)

226/0150

Water Resources Act 1991

as amended by the Environment Act 1995

Consent to Discharge

Part A

To: Northumbrian Water Limited
Abbey Road
Pity Me
Durham
DH1 5FJ

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent reference number 226/0150

Nature of Discharge(s); Treated Sewage Effluent at Wallridge Sewage Disposal Works, Wallridge

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To: The Environment Agency, Tyneside House, Skinnerburn Road, Newcastle Business Park, Newcastle Upon Tyne, NE4 7AR

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent 226/0150 Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to: _____

- delete as appropriate

Name(s) of new holder(s):
Address:

Post Code:

Date of Transfer to new Holder(s);

Signed:..... **Dated:**

Name (block capitals):..... **Position:**

(to be completed when signing on behalf of corporate bodies)



DEPARTMENT OF THE ENVIRONMENT


CONTROL OF POLLUTION ACT 1974 - SECTION 34

THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES) REGULATIONS 1984

CONSENT FOR A DISCHARGE

1. The NORTHUMBRIAN WATER AUTHORITY (hereinafter referred to as "the Water Authority") proposes to discharge sewage effluent from Wallridge sewage treatment works to Cleugh Burn at National Grid Reference NZ 059 764 in accordance with the application dated 23 April 1985.
2. The proposal requires the consent of the Secretary of State for the Environment in pursuance of Section 34 of the Control of Pollution Act 1974 and the Control of Pollution (Discharges by Authorities) Regulations 1984.
3. THE SECRETARY OF STATE FOR THE ENVIRONMENT hereby consents to the proposed discharge subject to the discharge conforming at all times to the terms of the certificate attached hereto.


Signed
On behalf of the Secretary of
State for the Environment

Dated this  day
of July 1985

DATE OF ENTRY
INTO REGISTER: 31 JULY 1985

THE CONTROL OF POLLUTION ACT 1974: SECTION 34THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES) REGULATIONS 1984CERTIFICATE ATTACHED TO A CONSENT FOR A DISCHARGE

On behalf of theNorthumbrian.....Water Authority I certify that, in respect of the discharge from the Authority's sewage treatment works atWallridge.....
(National Grid ReferenceNZ 059 764.....):

1. The effluent derives from domestic sewage from a population of 250 or less and contains no authorised trade waste.

2. There are no potable water supply intakes downstream which are likely to be adversely affected.

3. As far as is reasonably practicable, the works shall be operated so as to prevent:

(i) any matter being present in the effluent which will cause the receiving water to be poisonous or injurious to fish or to their spawn, or spawning grounds or food, or otherwise cause damage to the ecology of the receiving waters; and

(ii) the treated effluent from having any other adverse environmental impact.

4. The Authority will operate the works having regard, so far as relevant, to the guidance set out in the National Water Council's Occasional Technical Paper Number 4, "The Operation and Maintenance of Small Sewage Works" dated January 1980. In particular the works shall be maintained properly such that:

(a) it remains fully operational except at times of mechanical or electrical breakdown;

(b) any such breakdowns shall be attended to promptly and the equipment returned to normal operation as soon as possible; and

(c) tanks shall be desludged at sufficient frequency and in such a manner as to prevent problems with septic tanks, rising sludge or excessive carryover of suspended solids.

Signed 
Authorised to sign on behalf of
the Authority

Dated this 23/4/ 1985
day of April