

NATIONAL RIVERS AUTHORITY P04638/1
S/01533

SOUTHERN REGION


THE WATER RESOURCES ACT 1991

TO: Swaythling Housing Association
Herbert Collins House
Wide Lane
Swaythling
Southampton
Hampshire
SO22 HR

In pursuance of its powers under Section 88 and Schedule 10 of the Water Resources Act 1991 the National Rivers Authority (hereinafter referred to as 'the Authority') HEREBY GRANTS CONSENT to a discharge of treated sewage effluent from an outlet at National Grid Reference SU74602906 from land a new development at Pococks Lane, Hawkley, Hampshire in accordance with Application No. P4638/S/CH/92 dated 1 December 1992 and the plans and particulars referred to therein subject to the conditions set out in the attached Schedule.

The terms of this consent shall not be altered within the period of two years beginning with the day on which they take effect unless the person who proposes to make or makes a discharge in pursuance of this Consent otherwise agrees.

Dated this 11th day of January 1993.

Signed.....
AREA ENVIRONMENTAL OFFICER
National Rivers Authority
Southern Region
Chichester Office
Oving Road
Chichester
West Sussex
PO20 6AG

SCHEDULE

1. Use

The outlet at National Grid Reference SU74602906 shall be used only for the discharge of **treated sewage** effluent into underground strata from the premises which are the subject of application no. P4638/S/CH/92 and shown on the plan numbered 92/11/4/1 submitted with the application.

2. Volume and Rate of Discharge

The volume of effluent discharged into underground strata shall not exceed 4.5 cubic metres in any period of 24 hours.

3. Other Conditions

- 3.1 The discharge to underground strata shall be by means of a sub-surface irrigation system, the maximum depth below ground level of which does not exceed one metre.
- 3.2 There shall be no discharge from the **sewage treatment plant** to a ditch, stream or other watercourse and the sub-surface irrigation system shall terminate at least 10m from any ditch, stream or other watercourse.
- 3.3 The **sewage treatment plant** shall be desludged at sufficient intervals and in such a manner so as to prevent the discharge of solid material to the sub-surface irrigation system.
- 3.4 Facilities for the taking of samples by the Authority's Officers shall be provided and maintained at the point indicated on the plan numbered 92/11/4/1 submitted with the application.

IMPORTANT NOTICES

1. Requirement to Notify Certain Changes in Particulars

Notice is hereby given under Section 202(2) of the Water Resources Act 1991 that the Authority requires to be notified in writing of any change in the particulars of the name or address of the person to whom this consent is given, or who makes or proposes to make any discharge to which it applies, within one month of the change taking effect. Failure to comply without reasonable cause is an offence punishable on summary conviction by a fine of up to £2,000.

2. Entry into Premises

In exercise of powers conferred by Section 169(1) Notice is hereby given under Schedule 20, Water Resources Act 1991 that, not less than seven days after this consent is given in the case of residential premises, a person designated in writing by the Authority may enter premises to which it applies at any reasonable time. It is an offence to intentionally obstruct a person acting in the exercise of this power punishable on summary conviction by a fine of up to £400.