



**ENVIRONMENT
AGENCY**

Consent to Discharge

Water Resources Act 1991

(As amended by the Environment Act 1995)

Thames Water Utilities Ltd
Clearwater Court
Vastern Road,
Reading,
RG1 8DB

Consent to Discharge from
Folkestone Road
East Ham

Consent Number

COPA/200127



CSBCQ/27

DEPARTMENT OF THE ENVIRONMENT

DOE FILE No. HMIP/29/130/74
COPA No. 200127

CONTROL OF POLLUTION ACT 1974 - SECTION 34
THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES)
REGULATIONS 1984

CONSENT FOR A DISCHARGE

1. The THAMES WATER AUTHORITY (hereinafter referred to as "the Water Authority") proposes to discharge sewage effluent in accordance with the application dated 19 August 1988.
2. The proposal requires the consent of the Secretary of State for the Environment in pursuance of section 34 of the Control of Pollution Act 1974 and the Control of Pollution (Discharges by Authorities) Regulations 1984.
3. The SECRETARY OF STATE FOR THE ENVIRONMENT hereby consents to the proposed discharge subject to the conditions set out in the schedule attached hereto.

Signed 
On behalf of the Secretary of
State for the Environment


Dated the 2 day
of June 1989

DOE FILE No. HMIP/29/130/74
COPA No. 200127

SCHEDULE

CONDITIONS PRESCRIBED FOR THE DISCHARGE OF SEWAGE EFFLUENT FROM
FOLKESTONE ROAD PUMPING STATION STORM TANKS TO RIVER RODING
(BARKING CREEK).

1. The effluent discharged shall consist only of storm sewage from an outlet at National Grid Reference TQ 4411 8319.
2. The effluent shall be discharged only when the rate of flow in the sewer is in excess of 1500 litres per second and shall consist only of the flow in excess of this figure after the flow has passed through storm tanks of a total volume of 6061 cubic metres.
3. Facilities shall be provided to the Secretary of State's representatives so as to enable samples of the effluent to be conveniently obtained.

Signed 
On behalf of the Secretary of
State for the Environment

Dated the 2 day
of June 1989