

# Notice of variation and consolidation with introductory note

**The Environmental Permitting (England & Wales) Regulations 2016**

---

Vauxhall Motors Limited

Vauxhall Motors Ltd  
North Rd  
Ellesmere Port  
Cheshire  
CH65 1AL

**Variation application number**

EPR/KP3627SZ/V002

**Permit number**

EPR/KP3627SZ

# Permit number EPR/KP3627SZ

## Introductory note

### **This introductory note does not form a part of the notice**

Under the Environmental Permitting (England & Wales) Regulations 2016 (schedule 5, part 1, paragraph 19) a variation may comprise a consolidated permit reflecting the variations and a notice specifying the variations included in that consolidated permit.

Schedule 1 of the notice specifies the conditions that have been varied and schedule 2 comprises a consolidated permit which reflects the variations being made. Only the variations specified in schedule 1 are subject to a right of appeal.

The variation is for the following:

- Increase in operating hours for all combustion plant; and
- Increase the emission limit value for NO<sub>x</sub> from the boilers.

This permit will allow the operator to operate:

- One or more medium combustion plant (MCP) between 1 and <50MWth but aggregated to <50MWth, and
- One Tranche B Specified Generator aggregated to <50MWth at a specified location.

The details of the units and associated limits and monitoring requirements are specified in Tables S1.1 and S3.1.

This is a complex permit and air dispersion modelling was required.

The site comprises two combined heat and power (CHP) engines fuelled by natural gas and five natural gas boilers. The CHP engines have a net rated thermal input of 1.5MWth and 2.5MWth. Each of the five boilers has a net rated thermal input of 1.95MWth. The aggregated thermal input of the facility is 13.75MWth.

The five boilers and the two CHP engines are classified as new Medium Combustion Plant (MCP) in accordance with Schedule 25A of the Environmental Permitting Regulations. The two CHP engines are also collectively classified as a Tranche B Specified Generator in accordance with Schedule 25B of the Environmental Permitting Regulations.

CHP 1 and CHP 2 operate for unlimited hours each. Emissions from each CHP are discharged through their own stacks which are 5.7 and 6 metres high respectively.

Boilers 1-5 operate for unlimited hours each. Emissions from each boiler are discharged from their own stacks, which are 6.7 metres high.

Vauxhall Motors Limited operate the CHP engines and boilers in order to generate electricity and heat for use on site. The site has a National Grid Reference (NGR) of 337972, 378737. The site is located in an industrial area and the nearest human receptor is situated approximately 700 metres southwest of the site.

Within the relevant screening distance of 1.5km from the site there are the following habitats sites: Mersey Estuary Ramsar, Mersey Estuary Special Protection Area and Mersey Estuary Site of Special Scientific Interest.

The schedules specify the changes made to the permit.

We consider that in reaching our decision to vary the permit we have taken into account all relevant considerations and legal requirements. We are satisfied that the permit will ensure that a high level of protection is provided for the environment and human health and that the activities will not give rise to any significant pollution of the environment or harm to human health.

| Status log of the permit                              |                         |                                                                                                               |
|-------------------------------------------------------|-------------------------|---------------------------------------------------------------------------------------------------------------|
| Description                                           | Date                    | Comments                                                                                                      |
| Application EPR/KP3627SZ/A001                         | Duly made<br>30/07/2024 | Bespoke application for MCP(s) and/or Specified Generators.                                                   |
| Additional information received                       | 08/08/2024              | Schedule 5 response received                                                                                  |
| Permit determined<br>EPR/KP3627SZ                     | 02/09/2024              | Permit issued to Vauxhall Motors Limited.                                                                     |
| Application variation<br>EPR/KP3627SZ/V002            | Duly made<br>08/12/2025 | Application to increase operating hours, change emission parameters and change emission limit for the boilers |
| Additional information                                | 13/01/2026              | Clarification of modelling inputs and confirmation of start of operations                                     |
| Variation application determined<br>EPR/KP3627SZ/V002 | 15/01/2026              | Varied and consolidated permit issued.                                                                        |

End of introductory note

# Notice of variation and consolidation

## The Environmental Permitting (England and Wales) Regulations 2016

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2016 varies

### Permit number

**EPR/KP3627SZ**

### Issued to

**Vauxhall Motors Limited** ("the operator")

whose registered office is

**Pinley House  
2 Sunbeam Way  
Coventry  
West Midlands**

**CV3 1ND**

company registration number 00135767

to operate one or more Medium Combustion Plant and a Specified Generator at

**Vauxhall Motors Ltd  
North Rd  
Ellesmere Port  
Cheshire  
CH65 1AL**

to the extent set out in the schedules.

The notice shall take effect from 15/01/2026

| Name          | Date       |
|---------------|------------|
| Daniel Timney | 15/01/2026 |

Authorised on behalf of the Environment Agency

## **Schedule 1**

The following conditions were varied as a result of the application made by the operator:

- Table S1.1, as referred to in condition 2.1.1, is varied to amend the operating hours
- Table S3.1, as referred to in conditions 3.1.1 and 3.2.1, is varied to amend the NOx emission limit for the boilers

## **Schedule 2 – consolidated permit**

Consolidated permit issued as a separate document.

# Permit

## The Environmental Permitting (England and Wales) Regulations 2016

### Permit number

**EPR/KP3627SZ**

This is the consolidated permit referred to in the variation and consolidation notice for application EPR/KP3627SZ/V002 authorising,

**Vauxhall Motors Limited** (“the operator”),

whose registered office is

**Pinley House  
2 Sunbeam Way  
Coventry  
West Midlands  
CV3 1ND**

company registration number 00135767

to operate one or more Medium Combustion Plant and Specified Generators at

**Vauxhall Motors Ltd  
North Rd  
Ellesmere Port  
Cheshire  
CH65 1AL**

to the extent authorised by and subject to the conditions of this permit.

| Name          | Date       |
|---------------|------------|
| Daniel Timney | 15/01/2026 |

Authorised on behalf of the Environment Agency

# Conditions

## 1 Management

### 1.1 General management

- 1.1.1 The operator shall manage and operate the activities:
- (a) in accordance with a written management system that identifies and minimises risks of pollution, so far as is reasonably practicable, including those arising from operations, maintenance, accidents, incidents, non-conformances, closure and those drawn to the attention of the operator as a result of complaints; and
  - (b) using sufficient competent persons and resources.
- 1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.
- 1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of it kept at or near the place where those duties are carried out.

## 2 Operations

### 2.1 Permitted activities

- 2.1.1 The operator is only authorised to carry out the activities specified in schedule 1, table S1.1 (the “activities”).

### 2.2 The site

- 2.2.1 No MCP shall be operated beyond the site of the grid reference specified for it in schedule 1, table S1.1 of the permit.

### 2.3 Operating techniques

- 2.3.1 The activities shall be operated using the techniques and in the manner described in schedule 1, tables S1.2A and S1.2B.

## 3 Emissions and monitoring

### 3.1 Emissions to water, air or land

- 3.1.1 There shall be no point source emissions to air except from the sources and emission points listed in schedule 3, table S3.1.
- 3.1.2 The limits given in schedule 3 shall not be exceeded.

### 3.2 Monitoring

- 3.2.1 The operator shall, unless otherwise agreed in writing by the Environment Agency, undertake the monitoring specified in the following tables in schedule 3 to this permit, or at a greater frequency if notified to the operator in writing by the Environment Agency:
- (a) point source emissions specified in table S3.1.
- 3.2.2 Monitoring shall not take place during periods of start up or shut down.

- 3.2.3 For new MCPs the first monitoring measurements shall be carried out within 4 months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later. For existing MCPs the first monitoring measurement shall be carried out at any time, but no later than the relevant compliance date.
- 3.2.4 The operator shall maintain records of all monitoring including records of the taking and analysis of samples, instrument measurements (periodic and continual), calibrations, examinations, test and surveys and any assessment or evaluation made on the basis of such data.

## **4 Information**

### **4.1 Records**

- 4.1.1 All records required to be made by this permit shall:
- (a) be legible;
  - (b) be made as soon as reasonably practicable;
  - (c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and
  - (d) be retained, unless otherwise agreed in writing by the Environment Agency, for at least 6 years from the date when the records were made.
- 4.1.2 The operator shall maintain convenient access, in either electronic or hard copy, to the records, plans and management system required to be maintained by this permit.
- 4.1.3 The operator shall maintain a record of the type and quantity of fuel used and the total annual hours of operation for each MCP and/or generator.
- 4.1.4 The operator shall maintain a record of any events of non-compliance and the measures taken to ensure compliance is restored in the shortest possible time.

### **4.2 Reporting**

- 4.2.1 The operator shall send all reports and notifications required by the permit to the Environment Agency using the contact details supplied in writing by the Environment Agency.
- 4.2.2 Within 28 days of the end of the reporting period the operator shall, unless otherwise agreed in writing by the Environment Agency, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:
- (a) in respect of the parameters and emission points specified in schedule 4, table S4.1;
  - (b) for the reporting periods specified in schedule 4, table S4.1 and using the forms specified in schedule 4, table S4.2; and
  - (c) giving the information from such results as required by the forms specified in those tables.

### **4.3 Notifications**

- 4.3.1 In the event:
- (a) of a breach of any of the permit conditions the operator must immediately—
    - (i) inform the Environment Agency, and
    - (ii) take the measures necessary to ensure that compliance is restored within the shortest possible time;

- (b) of a breach of any of the permit conditions which causes a significant degradation of local air quality, the operator must immediately suspend the operation of the activities or the relevant part of them until compliance with the conditions has been restored.

4.3.2 Any information provided under condition 4.3.1 shall be confirmed by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.

4.3.3 Where the Environment Agency has requested in writing that it shall be notified when the operator is to undertake monitoring and/or spot sampling, the operator shall inform the Environment Agency when the relevant monitoring and/or spot sampling is to take place. The operator shall provide this information to the Environment Agency at least 14 days before the date the monitoring is to be undertaken.

4.3.4 The Environment Agency shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:

Where the operator is a registered company:

- (a) any change in the operator's trading name, registered name or registered office address; and
- (b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.

Where the operator is a corporate body other than a registered company:

- (c) any change in the operator's name or address; and
- (d) any steps taken with a view to the dissolution of the operator.

In any other case:

- (e) the death of any of the named operators (where the operator consists of more than one named individual);
- (f) any change in the operator's name(s) or address(es); and
- (g) any steps taken with a view to the operator, or any one of them, going into bankruptcy, entering into a composition or arrangement with creditors, or, in the case of them being in a partnership, dissolving the partnership.

## 4.4 Interpretation

4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.

4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made "immediately", in which case it may be provided by telephone.

# Schedule 1 – Operations

| <b>Table S1.1 activities</b>                                                                                                                                                           |                                                                                     |                                                      |             |                                       |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|------------------------------------------------------|-------------|---------------------------------------|
| <b>National Grid Reference and or activity reference/ emission point</b>                                                                                                               | <b>Activity listed in the EP Regulations</b>                                        | <b>Description of MCP and/or specified generator</b> | <b>Fuel</b> | <b>Operating hours limit per year</b> |
| CHP 1<br>NGR SJ 37954 78751                                                                                                                                                            | Schedule 25A – MCP as detailed in Schedule 7 and Schedule 25B – Specified generator | 1 x 1.5MWth CHP engine                               | Natural gas | Unlimited                             |
| CHP 2<br>NGR SJ 37958 78755                                                                                                                                                            | Schedule 25A – MCP as detailed in Schedule 7 and Schedule 25B – Specified generator | 1 x 2.5MWth CHP engine                               | Natural gas | Unlimited                             |
| Boiler 1<br>NGR SJ 37977 78727<br><br>Boiler 2<br>NGR SJ 37978 78726<br><br>Boiler 3<br>NGR SJ 37980 78724<br><br>Boiler 4<br>NGR SJ 37981 78723<br><br>Boiler 5<br>NGR SJ 37983 78722 | Schedule 25A – MCP as detailed in Schedule 7                                        | 5 x 1.95MWth engines                                 | Natural gas | Unlimited                             |

| <b>Table S1.2A Operating techniques for Medium Combustion Plant as detailed in Schedule 7</b>                                                                                                                                                                                                                                                                                  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>(a) Each MCP must be operated in accordance with the manufacturer's instructions and records must be made and retained to demonstrate this.</p> <p>(b) The operator must keep periods of start-up and shut-down of each MCP as short as possible.</p> <p>(c) There must be no persistent emission of 'dark smoke' as defined in section 3(1) of the Clean Air Act 1993.</p> |

| <b>Table S1.2B Operating techniques for Specified Generators</b>                                                                                                                                                                                                                                                                                                                                                                                                |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>(a) Each generator must be operated in accordance with the manufacturer's instructions and records must be made and retained to demonstrate this.</p> <p>(b) The operator must keep periods of start-up and shut down of the generators as short as possible</p> <p>(c) There must be no persistent emission of 'dark smoke' as defined in section 3(1) of the Clean Air Act 1993.</p> <p>(d) The stack must be vertical and unimpeded by cowls or caps.</p> |

## **Schedule 2 – Waste types, raw materials and fuels**

This schedule is not used

## Schedule 3 – Emissions and monitoring

| Table S3.1 Point source emissions to air – emission limits and monitoring requirements                                                                                                                                                                                                           |                                                                                                                 |                                                                           |                        |                                                                                                                       |                      |                                                                                                                           |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|------------------------|-----------------------------------------------------------------------------------------------------------------------|----------------------|---------------------------------------------------------------------------------------------------------------------------|
| Emission point ref. & location                                                                                                                                                                                                                                                                   | Source/technology                                                                                               | Parameter                                                                 | Limit (including unit) | Reference period                                                                                                      | Monitoring frequency | Monitoring standard or method<br>Note 1                                                                                   |
| CHP 1<br><br>CHP 2                                                                                                                                                                                                                                                                               | New medium combustion plant which are engines and gas turbines fuelled on natural gas and a specified generator | Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> ) | 95 mg/m <sup>3</sup>   | In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators<br>Published 20 March 2024 | Every 3 years        | In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators<br><br>Published 20 March 2024 |
|                                                                                                                                                                                                                                                                                                  |                                                                                                                 | Carbon monoxide                                                           | No limit set           |                                                                                                                       |                      |                                                                                                                           |
| Boiler 1<br><br>Boiler 2<br><br>Boiler 3<br><br>Boiler 4<br><br>Boiler 5                                                                                                                                                                                                                         | New medium combustion plant other than engines and gas turbines fuelled on natural gas                          | Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> ) | 100 mg/m <sup>3</sup>  | In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators<br>Published 20 March 2024 | Every 3 years        | In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators<br><br>Published 20 March 2024 |
|                                                                                                                                                                                                                                                                                                  |                                                                                                                 | Carbon monoxide                                                           | No limit set           |                                                                                                                       |                      |                                                                                                                           |
| Note 1:<br>Monitoring requirements are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O <sub>2</sub> content of 6% for solid fuels, 15% for engines and gas turbines and 3% all other MCPs |                                                                                                                 |                                                                           |                        |                                                                                                                       |                      |                                                                                                                           |

## Schedule 4 – Reporting

Parameters, for which reports shall be made, in accordance with conditions of this permit, are listed below.

| <b>Table S4.1 Reporting of monitoring data</b>                 |                                                               |                         |                      |
|----------------------------------------------------------------|---------------------------------------------------------------|-------------------------|----------------------|
| <b>Parameter</b>                                               | <b>Emission or monitoring point/reference</b>                 | <b>Reporting period</b> | <b>Period begins</b> |
| Emissions to air<br>Parameters as required by condition 3.2.1. | CHP1, CHP2, Boiler 1, Boiler 2, Boiler 3, Boiler 4, Boiler 5. | Every 3 years           | 1 January            |

| <b>Table S4.2 Reporting forms</b> |                                                                                              |                       |
|-----------------------------------|----------------------------------------------------------------------------------------------|-----------------------|
| <b>Media/parameter</b>            | <b>Reporting format</b>                                                                      | <b>Date of form</b>   |
| Air                               | Emissions to Air Reporting Form or other form as agreed in writing by the Environment Agency | Version 1, 08/03/2021 |

## Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

### Part A

|                                |  |
|--------------------------------|--|
| Permit Number                  |  |
| Name of operator               |  |
| Location of Facility           |  |
| Time and date of the detection |  |

|                                                                                                                                                                                                                                                     |  |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| <b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution</b> |  |
| <b>To be notified within 24 hours of detection</b>                                                                                                                                                                                                  |  |
| Date and time of the event                                                                                                                                                                                                                          |  |
| Reference or description of the location of the event                                                                                                                                                                                               |  |
| Description of where any release into the environment took place                                                                                                                                                                                    |  |
| Substances(s) potentially released                                                                                                                                                                                                                  |  |
| Best estimate of the quantity or rate of release of substances                                                                                                                                                                                      |  |
| Measures taken, or intended to be taken, to stop any emission                                                                                                                                                                                       |  |
| Description of the failure or accident.                                                                                                                                                                                                             |  |

|                                                                                     |  |
|-------------------------------------------------------------------------------------|--|
| <b>(b) Notification requirements for the breach of a limit</b>                      |  |
| <b>To be notified within 24 hours of detection unless otherwise specified below</b> |  |
| Emission point reference/ source                                                    |  |
| Parameter(s)                                                                        |  |
| Limit                                                                               |  |
| Measured value and uncertainty                                                      |  |
| Date and time of monitoring                                                         |  |

|                                                                                     |  |
|-------------------------------------------------------------------------------------|--|
| <b>(b) Notification requirements for the breach of a limit</b>                      |  |
| <b>To be notified within 24 hours of detection unless otherwise specified below</b> |  |
| Measures taken, or intended to be taken, to stop the emission                       |  |

|                                                                                 |                            |
|---------------------------------------------------------------------------------|----------------------------|
| <b>Time periods for notification following detection of a breach of a limit</b> |                            |
| <b>Parameter</b>                                                                | <b>Notification period</b> |
|                                                                                 |                            |
|                                                                                 |                            |
|                                                                                 |                            |

|                                                                                                |  |
|------------------------------------------------------------------------------------------------|--|
| <b>(c) Notification requirements for the breach of permit conditions not related to limits</b> |  |
| <b>To be notified within 24 hours of detection</b>                                             |  |
| Condition breached                                                                             |  |
| Date, time and duration of breach                                                              |  |
| Details of the permit breach i.e. what happened including impacts observed.                    |  |
| Measures taken, or intended to be taken, to restore permit compliance.                         |  |

|                                                                                                        |  |
|--------------------------------------------------------------------------------------------------------|--|
| <b>(d) Notification requirements for the detection of any significant adverse environmental effect</b> |  |
| <b>To be notified within 24 hours of detection</b>                                                     |  |
| Description of where the effect on the environment was detected                                        |  |
| Substances(s) detected                                                                                 |  |
| Concentrations of substances detected                                                                  |  |
| Date of monitoring/sampling                                                                            |  |

## Part B – to be submitted as soon as practicable

|                                                                                  |  |
|----------------------------------------------------------------------------------|--|
| Any more accurate information on the matters for notification under Part A.      |  |
| Measures taken, or intended to be taken, to prevent a recurrence of the incident |  |

|                                                                                                                                                        |  |
|--------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission |  |
| The dates of any unauthorised emissions from the facility in the preceding 24 months.                                                                  |  |

|           |  |
|-----------|--|
| Name*     |  |
| Post      |  |
| Signature |  |
| Date      |  |

\* authorised to sign on behalf of the operator

## Schedule 6 – Interpretation

“accident” means an accident that may result in pollution.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“authorised officer” means any person authorised by the Environment Agency under section 108(1) of The Environment Act 1995 to exercise, in accordance with the terms of any such authorisation, any power specified in section 108(4) of that Act.

“combined heat and power” (CHP) or Cogeneration means the simultaneous generation in one process of thermal energy and electrical or mechanical energy.

“compliance date” means 01/01/2025 for existing MCPs and a tranche A specified generator with net rated thermal input of greater than 5MW or 01/01/2030 for existing MCPs and a tranche A specified generator with a net rated thermal input of less than or equal to 5MW.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2016 No.1154 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“existing MCP” means an MCP first put into operation before 20/12/2018.

“first put into operation” means that the plant must have been fired with its design fuel up to its full load. This can be, but does not have to be, during commissioning.

“gas oil” includes diesel and is defined in Article 3(19) of the MCPD.

“medium combustion plant” or “MCP” means a combustion plant with a rated thermal input equal to or greater than 1 MW but less than 50 MW.

“Medium Combustion Plant Directive” or “MCPD” means Directive 2015/2193/EU of the European Parliament and of the Council on the limitation of emissions of certain pollutants into the air from medium combustion plants, as read in accordance with Schedule 1A to the Environmental Permitting (England and Wales) Regulations 2016.

“new MCP” means an MCP first put into operation on or after 20/12/2018.

“operating hours” means the time, expressed in hours, during which a combustion plant is operating and discharging emissions into the air, excluding start-up and shut-down periods.

“quarter” means a calendar year quarter commencing on 1 January, 1 April, 1 July or 1 October.

“specified generator” has the meaning given in paragraph 2(1) of Schedule 25B of The EP Regulations.

“tranche A generator” has the meaning given in paragraph 3(3) of schedule 25B of The EP Regulations.

“tranche B generator” is any generator that is not a Tranche A generator.

“year” means calendar year ending 31 December.

## Schedule 7 – Annex 1 of MCPD

|                                                                                                                                                                                                                                        |                                                                                                                                                                                                                                            |                                             |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------|
| 1. Rated thermal input (MW) of the medium combustion plant.                                                                                                                                                                            | CHP 1: 1.5MWth<br>CHP 2: 2.5MWth                                                                                                                                                                                                           | Boilers 1-5: each is 1.95MWth               |
| 2. Type of the medium combustion plant (diesel engine, gas turbine, dual fuel engine, other engine or other medium combustion plant).                                                                                                  | Other engine                                                                                                                                                                                                                               | Boiler                                      |
| 3. Type and share of fuels used according to the fuel categories laid down in Annex II.                                                                                                                                                | Natural gas 100%                                                                                                                                                                                                                           | Natural gas 100%                            |
| 4. Date of the start of the operation of the medium combustion plant or, where the exact date of the start of the operation is unknown, proof of the fact that the operation started before 20 December 2018.                          | CHP 1: 09/03/2025<br>CHP 2: 14/04/2025                                                                                                                                                                                                     | Boilers 1-5: 17/02/2025                     |
| 5. Sector of activity of the medium combustion plant or the facility in which it is applied (NACE code).                                                                                                                               | C29.1                                                                                                                                                                                                                                      | C29.1                                       |
| 6. Expected number of annual operating hours of the medium combustion plant and average load in use.                                                                                                                                   | CHP 1: unlimited hours, 100% load<br><br>CHP 2: unlimited hours, 100% load                                                                                                                                                                 | Boiler 1-5: unlimited hours each, 100% load |
| 7. Where the option of exemption under Article 6(3) or Article 6(8) is used, a declaration signed by the operator that the medium combustion plant will not be operated more than the number of hours referred to in those paragraphs. | N/A                                                                                                                                                                                                                                        | N/A                                         |
| 8. Name and registered office of the operator and, in the case of stationary medium combustion plants, the address where the plant is located.                                                                                         | <b>Operator:</b> Vauxhall Motors Limited<br><br><b>Registered office:</b><br>Pinley House, 2 Sunbeam Way, Coventry, West Midlands, CV3 1ND<br><br><b>Site address:</b><br>Vauxhall Motors Ltd, North Rd, Ellesmere Port, Cheshire CH65 1AL |                                             |

END OF PERMIT