

WIMS NO / EDRM CASE REFERENCE:

AW5NF689

PERMIT NO / EDRM OTHER REFERENCE:

ADDITIONAL REF:

REGISTER OF CONDITIONS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951.

AW/5/NF No. 689

SHAW & SONS LTD., PRINTER LONDON, E.C. 4. 97/3

NAME AND ADDRESS OF APPLICANT Anglian Water Authority, Northampton Sewage Division, Oxford House, Oxford Street, Wellingborough, Northants.		DATE OF APPLICATION
DATE ON WHICH CONDITIONS CAME INTO FORCE 12th September 1979	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE CONDITIONS RELATE in respect of a discharge of sewage effluent, namely screened crude sewage from the Desborough Sewage Pumping Station, Desborough.	
USE OF NEW OR ALTERED OUTLET		NEW DISCHARGE
CONDITIONS IMPOSED WITH RESPECT TO:- (i) PRECISE LOCATION OF OUTLET The Anglian Water Authority propose to make a discharge of sewage effluent, namely screened crude sewage from the Desborough Sewage Pumping Station, Desborough, through a 600 mm. diameter asbestos concrete outlet to the River Ise at Grid Reference SP 8094 8260, subject to the condition that a discharge shall not be made when the rate of flow of sewage to the Desborough Sewage Pumping Station is less than 105 litres per second, except when, by reason of a mechanical or electrical failure or break-down at the Desborough Sewage Pumping Station, it is not possible to pump sewage to the Rothwell Sewage Treatment Works. (ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) (iii) USE OF OUTLET (iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES		CONDITIONS IMPOSED WITH RESPECT TO:- (i) NATURE AND COMPOSITION OF DISCHARGE (ii) TEMPERATURE OF DISCHARGE (iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES REMARKS:- Application despatched to the Department of the Environment on 5th April 1979, amendment suggested on 1st June by the Department, agreed to by Anglian Water Authority in letter of 12th June - further letter from Department on 18th September stating Consent now completed statutory procedure.