

Permit

The Environmental Permitting (England & Wales) Regulations 2016

Thames Water Utilities Ltd
East Hyde STW
West Hyde Road
East Hyde
Luton
LU1 3TS

Permit number

EB3995YA

Permit

The Environmental Permitting (England and Wales) Regulations 2016

Permit number

EB3995YA

The Environment Agency hereby authorises, under regulation 13 of the Environmental Permitting (England and Wales) Regulations 2016

Thames Water Utilities Ltd (“the operator”),

whose registered office/principal office is

Clearwater Court

Vastern Road

Reading

RG1 8DB

company registration number 2366661

to operate a Specified Generator / Medium Combustion Plant described in standard rules SR2018 No 7 at

East Hyde STW

West Hyde Road

East Hyde

Luton

LU1 3TS

to the extent authorised by and subject to the conditions of this permit.

Under regulation 27(2) of the Regulations, standard rules **SR2018 No 7** are conditions of this permit.

This permit shall take effect from 27/07/2020

Name	Date
Vicky Hind – Senior Technical Officer Climate Change Trading & Regulatory Services – Warrington	27 July 2020

Authorised on behalf of the Environment Agency

Permit: EB3995YA - Appendix A

Medium Combustion Plant List (Annex 1 Information)

Operator Name: Thames Water Utilities Ltd

Operator Registered Office: Clearwater Court, Vastern Road, Reading, RG1 8DB

Address of Plant (Site): East Hyde STW, West Hyde Road, East Hyde, Luton, LU1 3TS

NACE Code: E.37 - Sewerage

Plant Name	Activity	Type of MCP (Technology) e.g. Diesel Engine, Gas Turbine, Dual Fuel Engine	Plant Grid Reference (Lat/Long) or (E/N)	Commissioning Date of MCP	Size (MWth) (Rated Thermal Input)	Fuel Type	Share of Fuels	Expected Annual Operating Hours
East Hyde MCP	MCP	Back up Generator (50h/yr Testing)	51.84841,- 0.372794	01/04/2019	1.562	Gas Oil	100%	49

Note:

This table only lists MCP Plant (including any SG Plant that is also an MCP) permitted on this site.

As outlined in 4.3.4 of the Standard Rule Set. The operator shall notify the Environment Agency, as soon as is practicable, in writing of any change of new medium combustion plant Annex I information. If this includes adding or removing MCP plant from the permitted site a variation of this standard permit will be required.

[If you have any queries please contact us at MCPDHelp@environment-agency.gov.uk](mailto:MCPDHelp@environment-agency.gov.uk)