



**ENVIRONMENT
AGENCY**

Consent to Discharge

Water Resources Act 1991 (as amended by the Environment Act 1995)

Consent Holder

Two Rivers Housing

7/3 Vantage Point Business Village

Mitcheldean

Gloucestershire

GL17 0DD

Consent to Discharge from

1-6 Council Houses

Brierley

Drybrook

Gloucestershire

GL17 9DL

Consent Number

NPSWQD008109

Consent to Discharge

Water Resources Act 1991
Section 88, Schedule 10
(as amended by the
Environment Act 1995)



**ENVIRONMENT
AGENCY**

Consent to Discharge

Consent Number
NPSWQD008109

To:
**Two Rivers Housing ("the Consent Holder")
7/3 Vantage Point Business Village
Mitcheldean
Gloucestershire
GL17 0DD**

The Environment Agency ("the Agency") in pursuance of its powers under the Water Resources Act 1991 (as amended by the Environment Act 1995) hereby consents to the making of a discharge:

Of:
Secondary treated sewage effluent containing no trade effluent ("the Discharge")

From:
The sewage treatment plant serving 6 domestic properties

At:
1-6 Council Houses, Brierley, Drybrook, Gloucestershire

To:
Drain to Greathough Brook

Subject to the conditions set out in this notice of Consent to Discharge.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991 (as amended by the Environment Act 1995), no notice shall be served by the Agency, altering this consent, without the agreement of the Consent Holder, during a period of 4 years from the date this notice is issued.

This Consent is granted on: **17th June 2009**

This Consent takes effect on: **17th June 2009**

Signed

Team Leader Permitting Support Centre

1 **Conditions of Consent for secondary treated sewage effluent containing no trade effluent**

1.1 **Nature**

1.1.1 The Discharge shall consist solely of secondary treated sewage effluent containing no trade effluent.

1.2 **Place of Discharge**

1.2.1 The Discharge shall be made in the manner and at the place specified as:

- a** discharging to Drain to Greathough Brook;
- b** at National Grid Reference SO 62079 14904;
- c** shown marked "OUTLET" on Site Plan attached to this consent.

1.3 **Volume**

1.3.1 The volume of the Discharge shall not exceed 4.86 cubic metres per day.

1.4 **Composition**

1.4.1 As far as is reasonably practicable, the sewage treatment plant shall be operated so as to prevent the Discharge from containing any visible oil or grease.

1.5 **British Standard**

1.5.1 The sewage treatment plant shall conform to all relevant British Standards in place at the time of installation.

1.6 **Works Operation**

1.6.1

- a** The sewage treatment plant shall be operated and the effluent shall be treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the discharge made from sewage treatment plant on controlled waters.
- b** This condition does not require any alteration of the sewage treatment plant or a change in the type of treatment used.

1.7 **Maintenance**

1.7.1 The sewage treatment plant shall be operated and maintained in accordance with good operational practice such that:

- a** it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
- b** following a failure all equipment shall be returned to normal operation as soon as practicable;
- c** tanks shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.

1.8

Recording and Reporting

1.8.1

- a** The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- b** On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality.

2

Site plan

