


REPORT ON CONSENTS (DETAILED) - PROGRAM CG1310B



Consent No : 050995

Status TRANSFERRED FROM R(PP)A 1951-1961

Date of Issue
Effective Date 20-MAY-83
Date Registered 21-AUG-85

First Date for Review 20-MAY-85
Expiry Date
Date of Revocation

REGISTER

Holder Address
THE NATIONAL TRUST
ESTATE OFFICE
HILLBUTTS
WIMBORNE
DORSET

Site Address
KINGSTON LACY HOUSE (WIMBORNE)
WIMBORNE
DORSET

Receiving Water:
NGR of Site Entrance ST9780001300
Site Type Domestic Property (Multiple)

lmOutlet No 1 0m

Receiving Environment
Catchment ALLEN

NGR of Outlet: ST9760015300

lmEffluent No 1 0m

1m 0m
Site Type SEWAGE DISCHARGES - SECONDARY/TERTIARY TREATMENT
Nature of Discharge TREATED DOMESTIC SEWAGE TO SUB-SURFACE IRRIGATION SYSTEM

NGR of Sampling Point: Archive Number
Description
Name

Maximum Volume 15.00 m3/day Dry Weather Flow 5.00 m3/day
Maximum Rate 1/s Overflow Setting 1/s

lmNumerical Limits0m
0085 BOD ATU Absolute
Maximum 50.00 mg/l Minimum
95 %ile Mean
Load Limit

0135 SUSPENDED SOLIDS 105C Absolute
Maximum 50.00 mg/l Minimum
95 %ile Mean
Load Limit

lmText Condition[s]0m

THE OUTLET SHALL ONLY BE USED FOR THE DISCHARGE OF TREATED DOMESTIC SEWAGE EFFLUENT.

REPORT ON CONSENTS (DETAILED) - PROGRAM CG1310B

Consent No : 050995

ImNon Standard Text Condition[s]0m

THE AGREED SAMPLING POINT FOR THE PURPOSES OF OBTAINING REPRESENTATIVE SAMPLES OF EFFLUENT SHALL BE THE DUMP CHAMBER ADJACENT TO THE SEWAGE TREATMENT UNIT AT THE POSITION MARKED POINT A ON THE ATTACHED LOCATION MAP (NRG:ST 9768 0137)