

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder

Part A

To:

Yorkshire Water Services Ltd
2 The Embankment
Sovereign Street
Leeds
West Yorkshire
LS1 4BG

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent **C4265**

Nature of Discharge(s): **FILTER BACKWASH WATER, SEPTIC TANK EFFLUENT**
at **JAW HILL FILTRATION WORKS.**

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To: **ENVIRONMENT AGENCY**

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:	Name:	Yorkshire Water Services Ltd
	Address:	2 The Embankment Sovereign Street Leeds West Yorkshire LS1 4BG

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):
Address:

Post Code:

Date of Transfer to new Holder(s);

Signed:..... **Dated:**

Name (block capitals):..... **Position:**

(to be completed when signing on behalf of corporate bodies)




DEPARTMENT OF THE ENVIRONMENT

CONTROL OF POLLUTION ACT 1974 - SECTION 34

THE CONTROL OF POLLUTION (DISCHARGES BY AUTHORITIES) REGULATIONS 1984

CONSENT FOR A DISCHARGE

1. The YORKSHIRE WATER AUTHORITY (hereinafter referred to as "the Water Authority") proposes to discharge sewage effluent from Jaw Hill Filtration Works to an unnamed tributary of Alverthorpe Beck at National Grid Reference SE 2902 2366 in accordance with the application dated 17 March 1986.
2. The proposal requires the consent of the Secretary of State for the Environment in pursuance of Section 34 of the Control of Pollution Act 1974 and the Control of Pollution (Discharges by Authorities) Regulations 1984.
3. THE SECRETARY OF STATE FOR THE ENVIRONMENT hereby consents to the proposed discharge subject to the conditions set out in the schedule attached hereto.

Signed 
On behalf of the Secretary of
State for the Environment

Dated this 8th day
of June 1986

SCHEDULE

CONDITIONS PRESCRIBED FOR THE DISCHARGE OF SEWAGE EFFLUENTS FROM JAW HILL FILTRATION WORKS TO AN UNNAMED TRIBUTARY OF ALVERTHORPE BECK

Nature of Effluents

1. The discharge shall consist only of filter backwash water and septic tank effluent either separately or in an admixture from an outlet at, National Grid Reference, SE 2902 2366.

2. Volume of Effluent

The volume of effluent discharged under dry weather conditions shall not exceed 350 cubic metres in any period of 24 hours.

3. Composition of Effluent

In any series of samples of the treated sewage effluent taken over any period of one year as listed in column 1 of the table set out in the annex to this schedule, no more than the relevant number of samples as permitted in column 2 of the said table shall contain:

- a. in excess of 60 milligrams per litre of suspended solids (measured after drying at 105 degrees Celsius);
- b. in excess of 15 milligrams per litre of biochemical oxygen demand (determined in the presence of 0.5 milligrams per litre of allyl-thiourea after 5 days at 20 degrees Celsius).

Taking of Samples

4. The Water Authority shall take samples of the treated sewage effluent in accordance with the relevant provisions of the Water Authority's sampling guidelines for the time being in force and approved for this purpose by the Secretary of State and shall keep records of such samples and the results of the analyses thereof for inspection by the Secretary of State's authorised representatives.

5. Facilities shall be provided to the Secretary of State's representatives so as to enable samples of the effluents to be conveniently obtained.

Rendering of Reports

6. The Water Authority shall, within 2 months of the end of each calendar year, notify the Department if any of the composition limits in condition 3 above have been exceeded and of the steps which have been taken or which it is proposed to take in consequence.

COPA(C) 6: MARCH 1955

ANNEX A

TABLE

(1)	(2)
Series of samples taken in any year	Maximum permitted number of samples which fail to conform to numerical limits
4-7	1
8-16	2
17-28	3
29-40	4
41-53	5
54-67	6
68-81	7
82-95	8
96-110	9
111-125	10
126-140	11
141-155	12
156-171	13
172-187	14
188-203	15
204-219	16
220-235	17
236-251	18
252-268	19
269-284	20
285-300	21
301-317	22
318-334	23
335-350	24
351-365	25