

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To:
NORTH WEST WATER LTD
DAWSON HOUSE
LIVERPOOL RD, GREAT SANKEY
WARRINGTON
CHESHIRE
WA5 3LW

Contact Name (if applicable): **ANGELA WELLS**
Registered as Joint Consent Holder: **No**
Number of discharges: **1**

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent **016891926** from **15 October 1997** Consent Alias (if applicable):
Sample Point Grid Reference: **SJ35727674**

Nature of Discharge(s): **EMERGENCY/CRUDE SEWAGE**

at **SEWAGE PUMPING STATION, DEVELOP ADJ TO ST JOSEPHS COLLEGE, WELSH ROAD, LITTLE SUTTON**

PLEASE NOTE: For Consents with Multiple Discharges, see the attached Schedule

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To: Environment Agency P.O. Box 12 Richard Fairclough House Knutsford Road Warrington WA4 1HG
Tel: 01925 653999 Fax: 01925 242209

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: **016891926**

Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s);

Signed: **Dated:**

Name (block capitals): **Position:**

JWE/S/96

(to be completed when signing
on behalf of corporate bodies)



S/CON/128/97

CONSENT NO.	016891926
-------------	-----------

CONSENT TO DISCHARGE

Water Resources Act 1991
 Section 88 - Schedule 10
 (as amended by the Environment Act 1995)



ENVIRONMENT
 AGENCY

TO: Redrow Homes (Northern) Ltd
 Redrow House
 Alltarni
 Mold
 Clwyd CH7 6RW

The ENVIRONMENT AGENCY ("The Agency") of 'Mirwell', Carrington Lane, Sale, M33 5NL in pursuance of its powers under the Water Resources Act 1991 HEREBY CONSENTS to the making of a discharge as follows:

Sewage in an Emergency

FROM: Sewage Pumping Station

AT: development adjacent to St Joseph's College, Welsh Road, Little Sutton

TO: Dibbinsdale Brook

SUBJECT TO: the conditions set out in the following schedule:
 Sewage in an Emergency 016891926-01

The Conditions attached to this consent hereby given will be subject to review from time to time.

This Consent is granted solely under and for the purpose of the Water Resources Act 1991 and is without prejudice to the operation of any other legal provisions now or at any other time hereinafter applicable to the aforesaid matter.

This Consent is a REINSTATEMENT of Consent number 016891632 issued on the 12 August 1991

Dated the 3rd day of December 1996.

Signed.....

S Taylor

District Pollution Control Manager

Mr George Ager - Area Manager South
 'Mirwell', Carrington Lane, Sale, M33 5NL. Tel: 0161 973 2237 Fax: 0161 973 4601

CONSENT NO.	016891926
SCHEDULE NO.	016891926-01
DATE REINSTATED	3 December 1996

CONDITIONS OF CONSENT TO DISCHARGE

Sewage in an Emergency ("the discharge")

**From: Sewage Pumping Station serving the development adjacent to St Joseph's College,
Welsh Road, Little Sutton**

1. GENERAL

1.1 Nature of discharge

The Discharge shall consist solely of sewage in an emergency.

The discharge shall only occur when the sewage pumping station is inoperative as a result of electrical power failure not due to the act or default of the discharger, its agents, representatives, officers, employees or servants and it is not reasonably practicable to dispose of the sewage otherwise. There shall be no undue delay on the part of the discharger in remedying any such failure or breakdown.

1.2 Place of discharge

The discharge shall be made in the manner and at the place specified as:

- (a) discharging to Dibbinsdale Brook
- (b) at National Grid Reference SJ 3572 7674

1.3 Sampling Point Requirements

The outlet to the watercourse shall be maintained so that a representative sample of the Discharge may be obtained at the agreed sample point provided prior to the confluence with the surface water sewer.

2. TELEMETRY

A 24 hour response telemetry alarm system shall be provided and maintained to give notification of failure or breakdown of the pumping station to a permanently manned office.