

# Notice of variation with introductory note

The Environmental Permitting (England & Wales) Regulations 2010

---

Wessex Water Services Limited

Waste water treatment works at  
Rode  
Frome  
Somerset  
BA2 7QN

Variation application number  
011560/V001

Permit number  
011560

# Waste Water Treatment Works at Rode

## Permit number 011560

### Introductory note

#### **This introductory note does not form a part of the notice**

The following notice gives notice of the variation of an environmental permit.

In 2005, Wessex Water applied to revise the permit for Rode Waste Water Treatment Works (permit number 011560). Subsequently, it has been realised that the storm tank capacity in the permit is different to the capacity Wessex Water applied for and is therefore not representative of what is actually at the site.

This was due to an Agency error during the amendment of the storm tank capacity condition, where the permit says 72 m<sup>3</sup> but the capacity applied for and actually installed was 46 m<sup>3</sup>.

This variation corrects the error in the storm tank capacity.

The schedules specify the changes made to the original permit.

The status log of a permit sets out the permitting history, including any changes to the permit reference number. It is not backdated before 6 April 2010.

#### **Status log of the permit**

<b>Description</b>	<b>Date</b>	<b>Comments</b>
Agency Led Variation form received	23/01/2013	To correct storm tank volume.
Variation determined 011560/V001	18/03/2013	Varied permit issued.

End of introductory note

## Notice of variation

The Environmental Permitting (England and Wales) Regulations 2010

The Environment Agency in exercise of its powers under regulation 20 of the Environmental Permitting (England and Wales) Regulations 2010 varies

**permit number**  
**011560**

**issued to:**  
**Wessex Water Services Limited** (“the operator”)

whose registered office is

**Operations Centre**  
**Claverton Down Road**  
**Claverton Down**  
**Bath**  
**BA2 7WW**

company registration number **02366648**

to operate a regulated facility at

**Rode Waste Water Treatment Works**  
**Rode**  
**Frome**  
**Somerset**  
**BA2 7QN**

to the extent set out in the schedules.

The notice shall take effect from 18/03/2013.

Name	Date
<b>Maria Stapley</b>	<b>18/03/2013</b>

Authorised on behalf of the Environment Agency

**Schedule 1 – conditions to be deleted**

None.

**Schedule 2 – conditions to be amended**

The following condition is amended as detailed, following an Environment Agency initiated variation:

15.1 The capacity of the storm tank(s) shall be at least 46 cubic metres.

**Schedule 3 – conditions to be added**

None.