CONSENT NO:	P.7293/S/CH/98

S/1703

P07293

THE WATER RESOURCES ACT 1991

SECTION 88 - SCHEDULE 10

CONSENT TO DISCHARGE

To: Highways Agency
Valuation Office
Westmoreland House
Strand Parade
Goring-by-Sea
Worthing
West Sussex

The **ENVIRONMENT AGENCY** ("the Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY CONSENTS** to the making of a discharge of **SEWAGE EFFLUENT**, as follows:-

Treated Sewage Effluent

FROM: Pinewoods, 58 Binstead Lane, Tortington Common, Arundel, West Sussex

AT: Land adjacent to Pinewoods, 58 Binstead Lane, Tortington Common, Arundel, West Sussex

TO: Ditch to tributary of the River Arun

SUBJECT TO the conditions set out in the following Schedules:

Treated Sewage Effluent Schedule No. P.7293 01

Subject to the provisions of paragraphs 6 and 7 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, altering this consent without the agreement in writing of the consent holder, during a period of 4 years from the date this consent takes effect or such later date as may be specified in an endorsement to this document.

This consent is issued and takes effect on the 14th day of August 1998

Signed.....

for AREA ENVIRONMENT PLANNING MANAGER

CONSENT NO:	P.7293/S/CH/98
SCHEDULE NO:	P.7293 01
DATE ISSUED:	14th August 1998

CONDITIONS OF CONSENT TO DISCHARGE

TREATED SEWAGE EFFLUENT ("the discharge").

FROM: Pinewoods, 58 Binstead Lane, Tortington Common, Arundel, West Sussex

1. (i) The discharge shall not contain any poisonous, noxious, or polluting matter or solid waste matter.

   (ii) Provided that the discharge hereby consented is made in accordance with the following conditions of this consent, such discharge shall not be taken to be in breach of condition (i) above by reason of containing substances or having properties identified in and controlled by those conditions.

2. The outlet shall be constructed and maintained in accordance with the plan numbered **P.7293** submitted by the Applicant.

3. The outlet at National Grid Reference **SU 9968 0665** shall be used only for the discharge of treated sewage effluent.

4. The effluent discharged to controlled waters shall at the specified sampling point comply with the following standard:

   (a) Biochemical Oxygen Demand (Allylthiourea) 5 days at 20 °C not to exceed **20** mg/l.

   (b) Suspended Solids dried at 105 °C not to exceed **30** mg/l.

5. As far as is reasonably practicable the works shall be operated so as to prevent:

   (a) any matter being present in the discharge, other than matter specifically covered by numerical conditions in this consent, to such an extent as to cause the receiving waters, or any waters of which the receiving waters are a tributary, to be poisonous or injurious to fish in those waters, or as to the spawning grounds, spawn or food of fish in those waters, or otherwise cause damage to ecology of those waters; and

   (b) the treated effluent from having any other adverse environmental impact.

CONSENT NO:	P.7293/S/CH/98
SCHEDULE NO:	P.7293 01
DATE ISSUED:	14th August 1998

6. The volume of effluent discharged shall not exceed **one** cubic metre in any period of 24 hours.

7. Facilities for the taking of samples by the Agency's Officers shall be provided and maintained at the **Sampling Point** indicated on the plan numbered **P.7293** submitted with the application.