

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. CR 1194

2848

CAT. NO. R.D.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
5th October 1972 (varied 27th August 1979)	Test Valley District Council, Duttons Road, Romsey, Hants. Cooks Lane, Lockerley, Oval Road S.T.W. H00039\1
USE OF NEW OR ALTERED OUTLET	DISCHARGE OF TRADE OR SEWAGE EFFLUENT
CONDITIONS IMPOSED WITH RESPECT TO:- (I) PRECISE LOCATION OF OUTLET SU 3042 2627 (II) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) (III) USE OF OUTLET The outlet at Grid Reference SU 3042 2627 shall be used only for the discharge of treated sewage effluent (IV) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES	CONDITIONS IMPOSED WITH RESPECT TO:- (I) NATURE AND COMPOSITION OF DISCHARGE The effluent discharged to the relevant waters shall comply with the following standard: - (a) Biochemical Oxygen Demand (Allylthiourea) in 5 days at 20°C not to exceed 40 mg/l (b) Suspended solids dried at 105°C not to exceed 60 mg/l (II) TEMPERATURE OF DISCHARGE (III) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES The volume of effluent discharged under dry weather conditions shall not exceed 35 cubic metres in any period of 24 hours * (IV) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the manhole immediately downstream of the treatment plant * (V) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT 27th August 1981
REMARKS-	REMARKS-

* IF DISCHARGE NOT CONTROLLED UNDER S.7 OF 1951 ACT

Cooks Lane, Lockerley
Oval Road S.T.W.

CK 1174
C.2848

SOUTHERN WATER AUTHORITY

RIVERS (PREVENTION OF POLLUTION) ACTS 1951-1961

To : Test Valley District Council,
Duttons Road,
Romsey,
Hants

TAKE NOTICE that the Southern Water Authority in exercise of the powers conferred on them by Section 5(1) of the Rivers (Prevention of Pollution) Act, 1961 have reviewed the conditions previously imposed by the former Hampshire River Authority in a consent granted to the Romsey and Stockbridge Rural District Council on the 5th October 1972 for the discharge of treated sewage effluent through an outlet at Grid Reference SU 3042 2627 and upon such review the Southern Water Authority have decided that the said conditions shall be varied in the manner and to the extent described in the Schedule hereto

The terms of this Notice will not without the consent in writing of the person to whom this consent is given (or his successor) be altered before the expiration of the period ending with the 27th day of August 1981

DATED this 27th day of August 1979

Signed

CHIEF SOLICITOR

Guildbourne House
Worthing
West Sussex
BN11 1LD

SCHEDULE

Variation or revocation of conditions

The conditions of the consent dated the 5th October 1972 are hereby revoked and the following conditions substituted therefor:-

Use:

The outlet at Grid Reference SU 3042 2627 shall be used only for the discharge of treated sewage effluent

Nature & Composition

The effluent discharged to the relevant waters shall comply with the following standard:-

(a) Biochemical Oxygen Demand (Allylthiourea) in 5 days at 20° C not to exceed 40 mg/l

(b) Suspended solids dried at 105° C not to exceed 60 mg/l

Volume or Rate of Discharges:

The volume of effluent discharged under dry weather conditions shall not exceed 35 cubic metres in any period of 24 hours.

Sampling Point:

Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the point indicated on the plan manhole immediately downstream of the treatment plant

REGISTER OF CONDITIONS

AND OTHER TERMS
IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

CAT. No. R.5/12 SHAW & SON, LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES	
5th October 1972 (varied 27th August 1979)	Test Valley District Council, Duttons Road, Romsey, Hants. Cooks Lane, Lockerley, Oval Road S.T.W.	
USE OF NEW OR ALTERED OUTLET		DISCHARGE OF TRADE OR SEWAGE EFFLUENT
CONDITIONS IMPOSED WITH RESPECT TO:- (i) PRECISE LOCATION OF OUTLET SU 3042 2627 (iii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) (iii) USE OF OUTLET The outlet at Grid Reference SU 3042 2627 shall be used only for the discharge of treated sewage effluent (iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES		CONDITIONS IMPOSED WITH RESPECT TO:- (ii) NATURE AND COMPOSITION OF DISCHARGE The effluent discharged to the relevant waters shall comply with the following standard: - (a) Biochemical Oxygen Demand (Allylthiourea) in 5 days at 20°C not to exceed 40 mg/l (b) Suspended solids dried at 105°C not to exceed 60 mg/l (iii) TEMPERATURE OF DISCHARGE (iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES The volume of effluent discharged under dry weather conditions shall not exceed 35 cubic metres in any period of 24 hours * (iv) PROVISION OF FACILITIES FOR TAKING SAMPLES Facilities for the taking of samples by the Authority's officers shall be provided and maintained at the manhole immediately downstream of the treatment plant * (v) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S.5(2) OF 1961 ACT 27th August 1981
REMARKS-		REMARKS-

* IF DISCHARGE NOT CONTROLLED UNDER S.7 OF 1951 ACT



**ENVIRONMENT
AGENCY**

Modification of Consent to Discharge

Water Resources Act 1991 (as amended by the Environment Act 1995)

Consent Holder(s)

Testway Housing Limited

**Testway House
Greenwich Way
Andover
Hampshire
SP10 4BF**

Consent to Discharge from

Oval Road and Butlers Close STW

**Cooks Lane
Lockerley**

Consent Number

CR1194 (H00039)

**Environment Agency – Southern Region, Hampshire & Isle of Wight Area Office,
Wessex Business Park, Wessex Way, Colden Common, Winchester SO21 1WP**

Telephone (08708) 506 506 Fax (01962) 841 573

Consent to Discharge

Water Resources Act 1991
Section 88, Schedule 10
(as amended by the
Environment Act 1995)



**ENVIRONMENT
AGENCY**

Modification of Consent to Discharge

Consent Number CR1194 (H00039)

To: Testway Housing Limited

Testway House
Greenwich Way
Andover
Hampshire
SP10 4BF

WHEREAS the Hampshire River Authority in pursuance of its powers under the Rivers' Prevention of Pollution Act 1951 **GRANTED CONSENT** to the making of a new discharge of Sewage effluent on the 5th day of October 1972.

From The Outlet to the River Dun at SU 3042 2627

The Agency in pursuance of its powers under the Water Resources Act 1991 (as amended by the Environment Act 1995) hereby **GIVES NOTICE** that **CONSENT** No CR1194 (H00039) is hereby varied as follows

Secondary treated sewage effluent containing no trade effluent ("the Discharge")

From: **The sewage treatment plant serving Oval Road and Butlers Close**

At: **Cooks Lane, Lockerley.**

To: **The River Dun**

The conditions of Consent No CR1194 (H00039) are hereby modified to be replaced by the conditions set out in the schedule attached to this notice.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991 (as amended by the Environment Act 1995), no notice shall be served by the Agency which alters the effects of modifications made by this notice, without the agreement of the Consent Holder, during a period of 4 years from the date this notice is issued.

This Consent is issued on: 04 January 2006

This Consent takes effect on: 04 January 2006

Signed

DAWN THEAKER - Team Leader Environment Management

1 **Schedule of Conditions, Consent for secondary treated sewage effluent containing no trade effluent**

1.1 **Nature**

1.1.1 The Discharge shall consist solely of secondary treated sewage effluent containing no trade effluent.

1.2 **Place of Discharge**

1.2.1

The Discharge shall be made in the manner and at the place specified as:

- a** discharging to the River Dún
- b** at National Grid Reference SU 3042 2627
- c** shown marked as "proposed headwall" on the plan numbered J1455/18/04 attached as annex 1 to this consent.

1.3 **Sampling Point Requirements**

1.3.1

1.3.2

A sample point shall be provided and maintained at National Grid Reference SU 3010 2609 as shown marked as "Sample and Flow Meter Chamber" on the Plan numbered J2000/04/10 rev A attached as annex 2 to this consent, so that a representative sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

1.4 **Volume**

1.4.1 The volume of the Discharge shall not exceed 52 cubic metres per day.

1.5 **Flow Measurement**

1.5.1

- a** At the request of the Agency, the Consent Holder shall install, operate and maintain a means of flow measuring to a specification and at a location required by the Agency, to enable the daily volume and/or instantaneous flow of sewage through the sewage treatment plant to be recorded.
- b** The Consent Holder shall calibrate, operate and maintain the flow monitoring and recording system to a standard agreed or specified by the Agency. The flow and maintenance records shall be provided to the Agency as and when requested.

1.6 **Composition**

1.6.1

The Discharge shall not contain more than:

- a** 40 milligrammes per litre of biochemical oxygen demand (measured after 5 days at 20°C with nitrification suppressed by the addition of allyl-thiourea)
- b** 60 milligrammes per litre of suspended solids (measured after drying at 105°C)

- 1.6.2 As far as is reasonably practicable, the sewage treatment plant shall be operated so as to prevent the Discharge from containing any significant trace of visible oil or grease.

1.7 **Priority Substances**

1.7.1

- a The quantity of Copper or Zinc in the Discharge shall not increase above the levels in the Discharge on the date of effect of this consent where no specific level is authorised; and
- b notwithstanding a above, the Discharge shall not contain quantities Copper or Zinc such as to cause or contribute to the concentration of that substance in the receiving water exceeding the relevant Environmental Quality Standard (EQS).

1.8 **Works Operation**

1.8.1

- a The sewage treatment plant shall be operated and the effluent shall be treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the Discharge made from the sewage treatment plant on controlled waters.
- b This condition does not require any alteration of the sewage treatment plant or a change in the type of treatment used from that specified in the application.

1.9 **Maintenance**

1.9.1

The sewage treatment plant shall be operated and maintained in accordance with good operational practice such that:

- a it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
- b following a failure all equipment shall be returned to normal operation as soon as practicable;
- c tanks shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.

1.10 **Recording and Reporting**

1.10.1

- a The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- b On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality.
- c The Consent Holder shall as soon as reasonably practicable report to the Agency all non-routine actions that may have adversely affected effluent quality.